

Gaviota Construction. Inc

Siding, Roofing, Gutters, Painting, Flooring, Dry wall & more.

1062 Arcade Street, Saint Paul, MN 55106

651-340-4682 Office * 651-787-3482 Fax 651 797 3482

To:	Gas Station / Khadra		Estimate			
Expect date	Open		Date:	10/08/15		
Address:	719 Payne Ave, St Paul. MN				Project #	172015
Telephone:	6517933568				License#	BC635994
Email:						
Type of Job:	Plumbing					
Item	Description	Sqs/EA	Cost Unit	Subtotal		
<u>The following bid included, materials & labor hands</u>						
1	The gas meter is at the rear of the building and is locked. Plumbing Trade.- Provide an approved number and type of plumbing fixtures. Plumbing Trade.- Repair or Replace and maintain the plumbing fixture to an operational condition.					
2	Water heater: corrections required. (MPC 2210 Subp. 4) -t & p relief discharge piping incorrect. (MPC 1730 Subp. 1) - water piping incorrect. (MPC 2180)- NOT FIRED OR IN SERVICE. Water piping: corrections required (MPC 1720)- Repair or replace all corroded, broken or leaking piping. (MPC 1730) - pipe sizing incorrect. (MPC 0420) - Improper fittings or usage. (MPC 0520)- Improper piping or usage. (MPC 1700)- Provide water piping to all fixture & appliances. Gas piping: corrections required: (MFGC 402) - Pipe sizing incorrect. (MEGC 406.1)-Retest all gas for excel meter unlock					
3	Set and Install according MN codes all piping and plumbing as need for new kitchen, (fixtures not included) and 1 bathroom, inside or building.					

Thanks For The Work Opportunity
License, Bonded, Insurance & BBB.
We will charge all additional job don't included in this bid.
We are dedicate to make only to quality job

Contact Us	Harold Fajardo (651) 3876951	Gross	\$12,633.00
	Office: (651) 447-2082 Fax: (651) 797-3482		
	harold@gaviotaconstruction.com		
	www.gaviotaconstruction.com	Total Bid	\$12,633.00