



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8585

RECEIVED

APR 15 2016

CITY CLERK

You need the following to process your appeal:

- \$25 filing fee (non-refundable) (payable to the City of Saint Paul) (if cash: receipt number CK# 19758)
 - Copy of the City-issued orders/letter being appealed
 - Attachments you may wish to include
 - This appeal form completed
 - Walk-In OR Mail-In
- for abatement orders only: Email OR Fax

HEARING DATE & TIME (provided by Legislative Hearing Office) Tuesday, <u>5-3-16</u> Time <u>1:30 p.m.</u> Location of Hearing: <u>Room 330 City Hall/Courthouse</u>
--

Address Being Appealed:

Number & Street: 1333 Randolph Ave. City: St. Paul State: MN Zip: 55105

Appellant/Applicant: Thomas & Sheila Casper Email mamasheshe@icloud.com

Phone Numbers: Business 651-690-0993 Residence 651-698-6964 Cell 651-707-4895

Signature: Sheila M. Casper Date: _____

Name of Owner (if other than Appellant): _____

Mailing Address if Not Appellant's: _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List/Correction Items 1 & 2 ✓ / Inherited violation from previous owner
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other (Fence Variance, Code Compliance, etc.)



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Telephone: 651-266-8989
Saint Paul, MN 55101-1806 Fax: 651-266-8951

April 6, 2016

COPPER
COOPER DOME

1333 RANDOLPH AVE
ST PAUL MN 55105-2957

Tommy C's Randolph Griddle

CORRECTION NOTICE - COMPLAINT INSPECTION

RE: 1333 RANDOLPH AVE
Ref. # 11519

Dear Property Representative:

A referral has been made to our office regarding code deficiencies that are reported to exist in your building or on the premises. An inspection has not been conducted by the Fire Prevention Division. If these deficiencies do in fact exist, you are hereby notified that the following deficiencies must be corrected immediately.

An inspection will be made on or after May 9, 2016.

DEFICIENCY LIST

1. FIRE ALARM REPORT - MSFC 907.20 as amended - Provide required annual maintenance of the fire alarm system by a qualified person and provide written documentation to this office as proof of compliance.
2. HOOD SUPPRESSION/FIRE ALARM - MSFC 904.3.5 - Where a building fire alarm system is installed, automatic fire extinguishing systems shall be monitored by the building fire alarm system in accordance with NFPA 72.

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: kris.skow-fiske@ci.stpaul.mn.us or call me at 651-266-8949 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Kris Skow-Fiske
Fire Inspector