



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

RECEIVED

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

APR 15 2016

Telephone: (651) 266-8585

CITY CLERK

We need the following to process your appeal:

- \$25 filing fee (non-refundable) (payable to the City of Saint Paul) (if cash: receipt number _____)
 - Copy of the City-issued orders/letter being appealed
 - Attachments you may wish to include
 - This appeal form completed
 - Walk-In OR Mail-In
- for abatement orders only: Email OR Fax

HEARING DATE & TIME

(provided by Legislative Hearing Office)

Tuesday, 4/24 @ 11AM

Time _____

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1627 MARSHALL City: ST. PAUL State: MN Zip: 55104

Appellant/Applicant: PHILIP VARCHENKO Email PHILIP AV @ MINDSPRING.

Phone Numbers: Business 651-644-2665 ext. 109 Residence 651-659-9406 Cell 612-388-9455 COM

Signature: [Handwritten Signature] Date: 4-15-2015

Name of Owner (if other than Appellant): _____

Mailing Address if Not Appellant's: _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List/Correction
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other (Fence Variance, Code Compliance, etc.)

multiple items on correction notice



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, MN 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-1919
Web: www.stpaul.gov/dsi

- Yog hais tias koj hais tsis to taub tsab ntawv no, hu rau tus txhais lus ntawm (651) 266-8989. Nws yog pab dawb zwb.
- Si necessita un traductor, por favor llamamos al (651)266-8989. No costo.

335

April 07, 2016

Phillip A Varchenko/Svetlana B Roman
1627 Marshall Ave
Saint Paul MN 55104-6222

CORRECTION NOTICE

RE: 1627 MARSHALL AVE
File #: 16-015770

Dear Sir or Madam:

The City of Saint Paul, Department of Safety and Inspections has inspected the above referenced property on April 07, 2016 and has determined that the following deficiencies exist in violation of the Saint Paul Legislative Code¹ (see footnote 1, below).

1. EXTERIOR WALLS: The exterior walls and/or trim of the house and/or garage has defective, peeled, flaked, scaled or chalking paint or has unpainted wood surfaces. Scrape and repaint to effect a sound condition in a professional manner. This is on the house and garage.
2. ROOF: The roof is deteriorated, defective, or in a state of disrepair. Repair or replace the roof covering to a sound, tight and water impervious condition. Permit may be required. This is on the house and garage.
3. WINDOW GLASS: The windows and/or storm windows are in a state of disrepair. Replace all missing or broken window glass. Make all necessary repairs to frames, sashes, hardware and associated trim in a professional manner. Permit may be required.
4. WINDOW SCREENS: The window and/or door screens are missing, defective or in a state of disrepair. Provide proper window and door screens for all openable windows and doors. Screens must be tight-fitting and securely fastened to the frames.
5. TALL GRASS AND WEEDS: Immediately cut tall grass and weeds which have grown to a height of eight (8) or more inches or have gone to seed. The Saint Paul Legislative code requires that grass be cut and maintained at a height of under eight (8) inches.
6. GARAGES AND ACCESSORY STRUCTURES. All garages and accessory structures must be in sound condition and secure from unauthorized entry. Repair or replace any missing doors, windows, or hardware for same.

7. The eaves and soffits are in a state of disrepair or deterioration. Repair all defects, holes, breaks, loose or rotting boards, to a professional state of maintenance. Permit may be required.

You are hereby notified to correct these deficiencies in accordance with the appropriate codes. The Enforcement Officer will re-inspect these premises on or after **May 09, 2016**, by which date the violations noted must be corrected. **Failure to correct these deficiencies may result in the issuance of criminal charges²** and/or a civil lawsuit, and possible abatement/assessment by the City. All repairs and new installations must be made in accordance with the appropriate codes. Permits may be obtained by calling 651-266-8989.

You may file an appeal to this notice by contacting the City Clerk at 651-266-8585. Any appeal must be made in writing within 10 days of this notice. (You must submit a copy of this Notice when you appeal, and pay a filing fee.)

If you have any questions or request additional information, please contact me. To arrange an appointment or request an extension of time to complete repairs, you will need to speak directly to me at 651-266-1940.

Sincerely,

Lisa Martin
Badge # 335

CODE ENFORCEMENT OFFICER

Footnotes:

- ¹ To see the Legislative Code go to www.stpaul.gov on the internet, click on "Departments", then click on "Department of Safety and Inspections", scroll down the page for the "Codes". Most Correction Notices derive from Chapter 34.
- ² Criminal charges can be brought on the day the violation is observed, but generally we allow time to correct unless this is a repeat violation.

lm

WARNING Code inspection and enforcement trips cost the taxpayers money. If the violations are not corrected within the time period required in this notice, the city's costs in conducting a reinspection after the due date for compliance will be collected from the owner rather than being paid by the taxpayers of the city. If additional new violations are discovered within the next following 12 months, the city's costs in conducting additional inspections at this same location within such 12 months will be collected from the owner rather than being paid by the taxpayers of the city. Any such future costs will be collected by assessment against the real property and are in addition to any other fines or assessments which may be levied against you and your property.