



APPLICATION FOR APPEAL

Saint Paul City Council - Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

RECEIVED
OCT 07 2016
CITY CLERK

We need the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____) *fee waived*
 - Copy of the City-issued orders/letter being appealed
 - Attachments you may wish to include
 - This appeal form completed
 - Walk-In OR Mail-In
- for abatement orders only: Email OR Fax

HEARING DATE & TIME (provided by Legislative Hearing Office) Tuesday, <u>October 18</u>
Time <u>2:30 p.m.</u>
Location of Hearing: <u>Room 330 City Hall/Courthouse</u>

Address Being Appealed:

Number & Street: 1372 N. Victoria St City: St. Paul State: MN Zip: 55117

Appellant/Applicant: Charles Bastel Email laura.orr@smrls.org
Attorney: Laura Orr

Phone Numbers: ~~Business~~ SMRLS 651-8946924 Residence _____ Cell _____

Signature: Laura Orr on behalf of Charles Bastel Date: 10/7/2016

Name of Owner (if other than Appellant): _____

Mailing Address if Not Appellant's: _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

Mr. Bastel asks that the vacant building registration be waived and that he be permitted to reoccupy his residence while working to address the city's concerns with the help of House Calls and friends.



CITY OF SAINT PAUL

Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, MN 55101- 1806

Telephone: 651- 266- 8989

Facsimile: 651- 266- 1919

www.stpaul.gov/dsi

September 29, 2016

Charles J Bastel
1372 Victoria St N
St Paul MN 55117- 4051

VACANT BUILDING REGISTRATION NOTICE

The premises at **1372 VICTORIA ST N**

has been inspected and found to meet the legal definition of a Vacant Building as described in Saint Paul Legislative Code, Chapter 43. You are required by law to register this building with the Department of Safety and Inspections, Vacant Building Division, by filling out and returning the registration form provided with this letter. You are also required to pay the annual Vacant Building Registration Fee of **\$2,085.00** . The fee is due upon receipt of this letter and must be paid no later than thirty (30) days from the date of this letter, as required in Saint Paul Legislative Code, Chapter 43. If this building is vacant due to a fire, complete the enclosed registration form and return it to this office within 30 days.

Please return the enclosed registration form along with your payment by October 29, 2016 .

Do Not Mail Cash

If you wish to pay in person, you may do so from 8:00am to 4:00pm Monday through Friday at:

DEPARTMENT OF SAFETY AND INSPECTIONS
375 Jackson Street, Suite 220
Saint Paul, MN 55101- 1806

You may file an appeal to this fee or registration requirements by contacting the City Clerk's Office by calling (651)266- 8688. Any appeal of this fee must be made within ten (10) days of the date of this notice.

If the registration fee is not received in this office within 45 days of the date of this letter, the full amount owed will be assessed to, and collected with, the taxes for this property as permitted by Saint Paul Legislative Code Chapter 43.

The Code Enforcement Officer has notified the Building Inspection and Design Section that this property meets the legal definition of a registered vacant building and in accordance with Legislative Code Chapter 33, no permits (except demolition, wrecking and removal permits) will be issued until the requirements of all applicable ordinances are fulfilled.

All category 2 and category 3 vacant buildings must be winterized with gas and water services shut off or, alternately, an excess flow gas valve must be installed in the dwelling, within sixty (60) days of the date of this notice.

WRITTEN PERMISSION FROM THE CITY OF SAINT PAUL IS REQUIRED BEFORE A CATEGORY 2 OR CATEGORY 3 VACANT BUILDING CAN BE OCCUPIED OR SOLD.

Category 2: Requirements include: 1. register/re-register the building, 2. pay outstanding fee(s), 3. obtain a code compliance report, 4. submit for approval a rehab cost estimate from a licensed contractor and a schedule for completion of all code compliance work, 5. submit proof of financial responsibility acceptable to the City, and 6. obtain Zoning approval of the proposed use.

Category 3: All requirements listed for Category 2 vacant buildings, AND obtain a **Certificate of Occupancy OR Certificate of Code Compliance** prior to the sale of the building.

If the use of this building meets the definition of a nonconforming use by the Zoning Code, then the use will lose its nonconforming status 365 days from the date the building was declared vacant.

You must contact the Enforcement officer , Matt Dornfeld, at 651- 266- 1902 to find out what must be done before this building can be legally reoccupied.

The Enforcement Officer may declare this building to constitute a Nuisance Building subject to demolition and issue an Order to Abate under authority of Legislative Code Chapter 45. In the event this building is declared a Nuisance Building, subject to demolition, the Enforcement Office will notify all owners and interested parties of the Order to Abate as provided in the Legislative Code Chapter 45.

If you have questions about this annual registration fee or other vacant building requirements, please contact the District Inspector, Matt Dornfeld, at 651- 266- 1902.

This registration form and fee is required by law. Your prompt attention to this matter is appreciated.

Steve Magner
Vacant Buildings Program Manager

Enclosures: Regulations Requirements Information
Vacant Building Registration Form

SM: md
vb_registration_notice 11/14



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, MN 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-1919
Web: www.stpaul.gov/dsi

335.0

September 7, 2016

NOTICE OF CONDEMNATION AS UNFIT FOR HUMAN HABITATION AND ORDER TO VACATE

Charles J Bastel
1372 Victoria St N
St Paul MN 55117-4051

Dear Sir or Madam:

The Department of Safety and Inspections, Division of Code Enforcement, has determined that the dwelling and premises at **1372 VICTORIA ST N** is "Unfit for Human Habitation". In accordance with Saint Paul Legislative Code, Chapter 34, Section 23, the premises will be placarded on **September 7, 2016** and ordered vacated no later than **September 21, 2016 at 11:00 a.m.**

Your attention is called to the following provisions of Section 34.23, Subsection 6 entitled, "Vacation of Structure or Unit":

"Any residential structure or residential unit which has been condemned or placarded as unfit for human habitation shall be vacated within the time set forth in the placard and/or order. It shall be unlawful for any person to let to any person for human habitation any structure or unit so condemned or placarded, and no person shall occupy the structure or unit after the date set forth in the placard and/or notice."

**THIS DWELLING SHALL NOT AGAIN BE USED FOR HUMAN HABITATION
UNTIL WRITTEN APPROVAL IS SECURED FROM THE CITY OF SAINT PAUL;
DEPARTMENT OF SAFETY AND INSPECTIONS, DIVISION OF CODE
ENFORCEMENT**

Principle Violations: These deficiencies must be corrected before this condemnation and vacate order will be removed.

1. CONDEMNATION: The interior of the house constitutes material endangerment. The interior of home has gross unsanitary/hoarding conditions. Inspector found the home filled with combustibles, counters cluttered, exits blocked, and no walking path throughout the home. This is also a fire hazard due to the excessive combustibles.
2. ACCESS. Allow access to the inspector of all areas of the property, home, and garage to inspect.

Other Violations: These deficiencies must be corrected in order to bring this property into compliance with the Saint Paul Legislative Code.

2. ADDRESS NUMBERS. The address posted is not visible from street. Or Provide address numbers on building.
3. The windows and/or storm windows are in a state of disrepair. Replace all missing or broken window glass. Make all necessary repairs to frames, sashes, hardware and associated trim in a professional manner. Permit may be required.
4. The window and/or door screens are missing, defective or in a state of disrepair. Provide proper window and door screens for all openable windows and doors. Screens must be tight-fitting and securely fastened to the frames.
5. The eaves and soffits are in a state of disrepair or deterioration. Repair all defects, holes, breaks, loose or rotting boards, to a professional state of maintenance. Permit may be required.
6. The exterior walls and/or trim of the house and/or garage has defective, peeled, flaked, scaled or chalking paint or has unpainted wood surfaces. Scrape and repaint to effect a sound condition in a professional manner.
7. GARAGES AND ACCESSORY STRUCTURES. All garages and accessory structures must be in sound condition and secure from unauthorized entry. Repair or replace any missing doors, windows, or hardware for same. Secure the garage or repair/remove under permit.
8. All vehicles including motorcycles and collector vehicles must be correctly licensed, operable, secure from unauthorized entry, and parked on an improved surface. Correct violations; store in a garage or remove.
9. TALL GRASS AND WEEDS: Immediately cut tall grass and weeds which have grown to a height of eight (8) or more inches or have gone to seed. The Saint Paul Legislative code requires that grass be cut and maintained at a height of under eight (8) inches.
10. VEGETATION: Cut and remove any overgrown vegetation including trees blocking the exit path and sidewalks.

11. **SANTITATION:** Immediately remove improperly stored or accumulated refuse including; garbage, rubbish, junk, vehicle parts, wood, metal, recycling materials, household items, building materials, rubble, tires, etc., from yard, vehicles, garage, driveway and property. The Saint Paul Legislative Code requires all exterior property areas to be maintained in a clean and sanitary condition. Usable materials must be stored in an approved manner, so as not to constitute a nuisance.

Authorization to reoccupy this/these dwelling unit(s) will not be given until it is demonstrated that all principal violations have been corrected and that no new conditions exist which could constitute material endangerment or which threaten the peace, health, safety or welfare of the occupants of this building.

All repairs and new installations must be made in accordance with the appropriate codes. Permit information may be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989.

You may file an appeal to this notice by contacting the City Clerk's Office at (651) 266-8688. Any appeal must be made in writing within 10 days of the date of this notice.

It is the responsibility of the property owner to keep all buildings secured and to properly maintain the premises at all times.

If you have any questions concerning this matter, please contact the Inspector, Lisa Martin, at 651-266-1940. To arrange an appointment or request an extension of time to complete repairs, you will need to speak directly to the inspector.

Sincerely,

Lisa Martin
Enforcement Officer

lm

c: Posted to ENS

uhh60103 4/11



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street., Suite 220
Saint Paul, MN 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-1919
Web: www.stpaul.gov/dsi

335.0

August 30, 2016

NOTICE OF CONDEMNATION AS UNFIT FOR HUMAN HABITATION AND ORDER TO VACATE

Charles J Bastel
1372 Victoria St N
St Paul MN 55117-4051

Dear Sir or Madam:

The Department of Safety and Inspections, Division of Code Enforcement, has determined that the dwelling and premises at **1372 VICTORIA ST N** is "Unfit for Human Habitation". In accordance with Saint Paul Legislative Code, Chapter 34, Section 23, the premises will be placarded on **August 30, 2016** and ordered vacated no later than **September 7, 2016 at 11:00 a.m.**

Your attention is called to the following provisions of Section 34.23, Subsection 6 entitled, "Vacation of Structure or Unit":

"Any residential structure or residential unit which has been condemned or placarded as unfit for human habitation shall be vacated within the time set forth in the placard and/or order. It shall be unlawful for any person to let to any person for human habitation any structure or unit so condemned or placarded, and no person shall occupy the structure or unit after the date set forth in the placard and/or notice."

**THIS DWELLING SHALL NOT AGAIN BE USED FOR HUMAN HABITATION
UNTIL WRITTEN APPROVAL IS SECURED FROM THE CITY OF SAINT PAUL;
DEPARTMENT OF SAFETY AND INSPECTIONS, DIVISION OF CODE
ENFORCEMENT**

Principle Violations: These deficiencies must be corrected before this condemnation and vacate order will be removed.

1. **CONDEMNATION:** The interior of the house constitutes material endangerment. The interior of home has gross unsanitary/hoarding conditions. Inspector found the home filled with combustibles, counters cluttered, exits blocked, and no walking path throughout the home. This is also a fire hazard due to the excessive combustibles.
2. **ACCESS.** Allow access to the inspector of all areas of the property, home, and garage to inspect.

Other Violations: These deficiencies must be corrected in order to bring this property into compliance with the Saint Paul Legislative Code.

2. **ADDRESS NUMBERS.** The address posted is not visible from street. Or Provide address numbers on building
3. The windows and/or storm windows are in a state of disrepair. Replace all missing or broken window glass. Make all necessary repairs to frames, sashes, hardware and associated trim in a professional manner. Permit may be required.
4. The window and/or door screens are missing, defective or in a state of disrepair. Provide proper window and door screens for all openable windows and doors. Screens must be tight-fitting and securely fastened to the frames.
5. The eaves and soffits are in a state of disrepair or deterioration. Repair all defects, holes, breaks, loose or rotting boards, to a professional state of maintenance. Permit may be required.
6. The exterior walls and/or trim of the house and/or garage has defective, peeled, flaked, scaled or chalking paint or has unpainted wood surfaces. Scrape and repaint to effect a sound condition in a professional manner.
7. **GARAGES AND ACCESSORY STRUCTURES.** All garages and accessory structures must be in sound condition and secure from unauthorized entry. Repair or replace any missing doors, windows, or hardware for same.
8. All vehicles including motorcycles and collector vehicles must be correctly licensed, operable, secure from unauthorized entry, and parked on an improved surface. Correct violations; store in a garage or remove.
9. **TALL GRASS AND WEEDS:** Immediately cut tall grass and weeds which have grown to a height of eight (8) or more inches or have gone to seed. The Saint Paul Legislative code requires that grass be cut and maintained at a height of under eight (8) inches.
10. **VEGETATION:** Cut and remove any overgrown vegetation including trees blocking the exit path and sidewalks.
11. **SANITATION:** Immediately remove improperly stored or accumulated refuse including; garbage, rubbish, junk, vehicle parts, wood, metal, recycling materials, household items, building materials, rubble, tires, etc., from yard, vehicles, garage, driveway and property. The Saint Paul Legislative Code requires all exterior property areas to be maintained in a clean and sanitary condition. Usable materials must be stored in an approved manner, so as not to constitute a nuisance.

Authorization to reoccupy this/these dwelling unit(s) will not be given until it is demonstrated that all principal violations have been corrected and that no new conditions exist which could constitute material endangerment or which threaten the peace, health, safety or welfare of the occupants of this building.

All repairs and new installations must be made in accordance with the appropriate codes. Permit information may be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989.

You may file an appeal to this notice by contacting the City Clerk's Office at (651) 266-8688. Any appeal must be made in writing within 10 days of the date of this notice.

It is the responsibility of the property owner to keep all buildings secured and to properly maintain the premises at all times.

If you have any questions concerning this matter, please contact the Inspector, Lisa Martin, at 651-266-1940. To arrange an appointment or request an extension of time to complete repairs, you will need to speak directly to the inspector.

Sincerely,

Lisa Martin
Enforcement Officer

lm

c: Posted to ENS

uhh60103 4/11