



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

November 20, 2014

CRYSTAL A JACKSON
CHARLES D JACKSON
3790 GRAND AVE
WHITE BEAR LAKE MN 55110-4915

**NOTICE OF CONDEMNATION
UNFIT FOR HUMAN HABITATION
ORDER TO VACATE**

RE: 662 3RD ST E
Ref. # 121346

Dear Property Representative:

Your building was inspected on November 20, 2014.

The building was found to be unsafe, unfit for human habitation, a public nuisance, a hazard to the public welfare or otherwise dangerous to human life. A Condemnation Placard has been posted on the building.

The following deficiency list must be completed or the building vacated by the re-inspection date.

CONDEMNATION OF THE BUILDING REVOKES THE CERTIFICATE OF OCCUPANCY.

Failure to complete the corrections may result in a criminal citation. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy.

DEFICIENCY LIST

1. Basement - SPLC 34.10 (7), 34.34 (6) - Repair and maintain the ceiling in an approved manner.-

2. Breaker box - NEC 408.7 Unused Openings. Unused openings for circuit breakers and switches shall be closed using identified closures, or other approved means that provide protection substantially equivalent to the wall enclosure.
3. East screen door - Ext. Door SPLC 34.09 (3), 34.33 (3) - Repair and maintain the door in good condition.-The door was missing a closer.
4. Exterior - Throughout - SPLC 34.09 (1) b,c, 34.33 (1) b, c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.-
5. First floor - Kitchen - SPLC 34.11, MSBC 2902.1, SPLC 34.17, MSPC 415.0220 - Repair or replace and maintain all parts of the plumbing system to an operational condition.- Remove the flex pipe from under the kitchen sink drain.
6. First floor - Living room - SPLC 34.10 (7), 34.34 (6) - Repair and maintain the ceiling in an approved manner.-
7. First floor and basement - SPLC 34.10 (7), 34.34 (6) - Repair and maintain the floor in an approved manner.-Repair or replace the carpeting that was water logged and had about one inch of standing water on it.
8. Interior - Throughout - SPLC 34.12 (2), SPLC 34.36 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition to properly and safely perform their intended function in accordance with the provisions of the applicable code. -The smoke detectors were hanging down from the wiring harness.
9. Interior - Throughout - SPLC 34.11, MSBC 2902.1, SPLC 34.17, MSPC 415.0220 - Repair or replace and maintain all parts of the plumbing system to an operational condition.- Repair the broken pipes under permit. Contact DSI at 266-8989 to obtain a permit and have the work approved.
10. Interior - Throughout - SPLC 34.11(4), 34.34(1) SPC 4715.0200A - Provide an adequate water supply to all water closets, sinks, showers and tubs.-The pipes were frozen and the fire department shut the water off to the building.
11. Lack of basic facilities - Water - SPLC 34.23, MSFC 110.1 - This occupancy is condemned as unfit for human habitation. This occupancy must not be used until re-inspected and approved by this office.-The pipes were frozen and the water was shut off by the fire department.
12. Second floor - South side - SPLC 34.09 (3), 34.33 (3) -Provide or repair and maintain the window screen.-
13. Second floor - North bedroom - MSFC 901.6 - Contact a fire sprinkler contractor to replace all painted or damaged fire sprinkler heads. All sprinkler work must be done by a licensed contractor under permit.-

14. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

15. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: george.niemeyer@ci.stpaul.mn.us or call me at 651-266-8991 between 7:30 - 9:00 a.m. Please help make Saint Paul a safer place in which to live and work.

Sincerely,

George Niemeyer
Fire Inspector
Ref. # 121346

cc: Housing Resource Center
Force Unit