



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street., Suite 220  
Saint Paul, MN 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-1919  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

325.0

January 30, 2017

## NOTICE OF CONDEMNATION AS UNFIT FOR HUMAN HABITATION AND ORDER TO VACATE - AMENDED

Bruce V Magnuson  
1271 Seminary Ave  
St Paul MN 55104-1443

Dear Sir or Madam:

The Department of Safety and Inspections, Division of Code Enforcement, has determined that the dwelling and premises at **1271 SEMINARY AVE** is "Unfit for Human Habitation". In accordance with Saint Paul Legislative Code, Chapter 34, Section 23, the premises will be placarded on **January 23, 2017** and ordered vacated no later than **January 30, 2017**.

Your attention is called to the following provisions of Section 34.23, Subsection 6 entitled, "Vacation of Structure or Unit":

**"Any residential structure or residential unit which has been condemned or placarded as unfit for human habitation shall be vacated within the time set forth in the placard and/or order. It shall be unlawful for any person to let to any person for human habitation any structure or unit so condemned or placarded, and no person shall occupy the structure or unit after the date set forth in the placard and/or notice."**

**THIS DWELLING SHALL NOT AGAIN BE USED FOR HUMAN HABITATION  
UNTIL WRITTEN APPROVAL IS SECURED FROM THE CITY OF SAINT PAUL;  
DEPARTMENT OF SAFETY AND INSPECTIONS, DIVISION OF CODE  
ENFORCEMENT**

**Principle Violations:** These deficiencies must be corrected before this condemnation and vacate order will be removed.

1. The interior ceilings are defective. Repair all ceiling defects and finish in a professional manner. Kitchen ceiling lathe water damaged, rotting and in areas missing.
2. The interior walls are defective. Repair all wall defects and finish in a professional manner. Loose, poorly fitting siding in the hallway leading to the basement.
3. The basement stairs have missing or defective handrails. Provide all interior and exterior stairways and steps of more than three (3) risers with handrails which are grippable and installed 34" to 38" above the nose of the stair treads.
4. The eaves and soffits are in a state of disrepair or deterioration. Repair all defects, holes, breaks, loose or rotting boards, to a professional state of maintenance. Permit may be required.
5. STORM DOOR(S): The storm door(s) are in disrepair; repair or replace the door(s).
6. DEFECTIVE STAIRS. Stairs in the attic are broken, defective, or in disrepair. Repair in a professional manner.
7. The window and/or door screens are missing, defective or in a state of disrepair. Provide proper window and door screens for all openable windows and doors. Screens must be tight-fitting and securely fastened to the frames.
8. The windows and/or storm windows are in a state of disrepair. Replace all missing or broken window glass. Make all necessary repairs to frames, sashes, hardware and associated trim in a professional manner. Permit may be required.
9. Clutter in the upper south bedroom closets and stairway leading to attic, constituting trip hazards.
10. Rear deck has rotting, loose boards.
11. Upper north balcony has an illegal railing, lacking balustrades.

**Other Violations:** These deficiencies must be corrected in order to bring this property into compliance with the Saint Paul Legislative Code.

2. NA

Authorization to reoccupy this/these dwelling unit(s) will not be given until it is demonstrated that all principal violations have been corrected and that no new conditions exist which could constitute material endangerment or which threaten the peace, health, safety or welfare of the occupants of this building.

All repairs and new installations must be made in accordance with the appropriate codes. Permit information may be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989.

You may file an appeal to this notice by contacting the City Clerk's Office at (651) 266-8688. Any appeal must be made in writing within 10 days of the date of this notice.

It is the responsibility of the property owner to keep all buildings secured and to properly maintain the premises at all times.

**If you have any questions concerning this matter, please contact the Inspector, Ed Smith, at 651-266-1917. To arrange an appointment or request an extension of time to complete repairs, you will need to speak directly to the inspector.**

Sincerely,

**Ed Smith**  
Enforcement Officer

es

c: Posted to ENS

uhh60103 4/11