



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

RECEIVED

JUL 31 2017

CITY CLERK

We need the following to process your appeal:

- \$25 filing fee (non-refundable) (payable to the City of Saint Paul) (if cash: receipt number _____)
 - Copy of the City-issued orders/letter being appealed
 - Attachments you may wish to include
 - This appeal form completed
 - Walk-In OR Mail-In
- for abatement orders only: Email OR Fax

HEARING DATE & TIME (provided by Legislative Hearing Office) Tuesday, <u>August 8</u>
Time <u>11:30 a.m.</u>
Location of Hearing: Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 869 Maryland Ave^E City: ST Paul State: MN Zip: _____

Appellant/Applicant: Ray Hatchett Email Rayan1Nova@yahoo.com

Phone Numbers: Business _____ Residence 763-657-0172 Cell 612-516-6323

Signature: Ray M Hatchett Date: 7-31-2017

Name of Owner (if other than Appellant): Sharon Valentine Hatchett

Mailing Address if Not Appellant's: _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List/Correction
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other (Fence Variance, Code Compliance, etc.)

Failure To Comply with list items 1 and 2 are due to me being Permenaly laid off after I agreed to address them by May 31st, 2017, so I do not have the money to pay out and get the garage or driveway repaired. I want to request time to have my tenants move out so I can sell the property as is.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

July 20, 2017

RAY A HATCHETT
SHARON V HATCHETT
1313 HILLWIND RD NE
FRIDLEY MN 55432-5916

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 869 MARYLAND AVE E
Ref. # 113844

Dear Property Representative:

Your building was inspected on July 20, 2017, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code.

A re-inspection will be made on August 18, 2017 at 11:30 AM or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

1. Exterior - Back of Garage - SPLC 34.08 (7) - All parking spaces shall be paved with asphalt, concrete, or durable dustless surfacing. Before any existing spaces may be paved, site plan approval must be obtained as specified in the St. Paul Zoning Code. Contact DSI Zoning at 651-266-9090.-Maintain the parking surface and the parking apron.

2. Exterior - Garage - SPLC 34.08(5), 34.32(3) - All accessory structures including, but not limited to, detached garages, sheds and fences shall be maintained structurally sound and in good repair. Provide and maintain exterior unprotected surfaces painted or protected from the elements.
The garage has chipping and peeling paint, broken boards with openings, cracked and damaged door trims and frames.
There is a fence that is in disrepair.
The window frame for the garage has chipping and peeling paint.
3. Interior - Basement - SPLC 34.11 (5), 34.34 (2) - Contact a licensed contractor to repair or replace the water heater. This work may require a permit(s). Call DSI at (651) 266-9090.-The water lines connected to the water heater are of the incorrect type. The water lines also have some corrosion developing.
4. **SPLC 40.06. - Suspension, revocation and denial. (a) Grounds for revocation. The fire code official may, in writing, issue a notice to the owner(s) and know interested parties of the city's suspension or revocation of a fire certificate of occupancy issued under the provisions of this code, or deny an application therefor: (3) If it is found upon inspection of the fire code official that the building or occupancy is in violation of provisions of this or other applicable safety codes, ordinances, rules and regulations;
The owner has failed to correct the required deficiencies and comply with the Legislative Hearing Officer's due date.**
5. MSBC -Section 105.1 - Permits Required. Any owner or authorized agent who intends to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, the installation of which is regulated by this code, or to cause any such work to be done, shall first make application to the building official and obtain the required permit. Work being done requires a permit.-A permit is required for the work performed on the water heater.
Ensure that the building permit is final.
6. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: Efrayn.Franquiz@ci.stpaul.mn.us or call me at 651-266-8955 between 8:00 a.m. - 9:30 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Efrayn Franquiz
Fire Inspector

Ref. # 113844