



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

August 20, 2012

SCOTT HUESTIS
2147 UNIVERSITY AVE W
ST PAUL MN 55114-1313

FIRE INSPECTION CORRECTION NOTICE

RE: 1685 TAYLOR AVE
Ref. #16008
Residential Class: B

Dear Property Representative:

Your building was inspected on August 20, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on October 1, 2012 at 10:30am.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Basement - Dryer - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989. **-Remove the screws and properly secure the vent. Vent is also pressure fitted between the air conditioner and its piping.**
2. Unit 1 and 2 – Door Separating Units - MSFC 705.1 - Provide a required occupancy separation with approved materials and methods. This work may require a permit(s). Call DSI at (651) 266-9090. **The minimum rating must be: 1 hour. Existing wood panel doors is separating the two units.**

3. SPLC 62.101 - Use of this property does not conform to zoning ordinance. Discontinue unapproved use or call DSI Zoning at (651) 266-8989 to convert to legal use.-Discontinue use of property as four (4) units and convert to legal occupancy of three (3) units. This includes:

-Remove the kitchen from the basement and all appliances. Remove and cap any gas lines if necessary.

- Provide approve occupancy separation between the first and second floor unit with approved fire rated construction materials. Wood panel door separating two units.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: adrian.neis@ci.stpaul.mn.us or call me at 651-266-8992 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

A.J. Neis
Fire Inspector

Reference Number 16008