DEPARTMENT SAFETY AND INSPECTIONS
Fire Inspection Division
Ricardo X. Cervantes, Director

CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, MN 55101-1806
Telephone: 651-266-8989
Fax: 651-266-8951

January 3, 2018

Roscoe Anderson
6316 Fallbrook Rd
Eden Prairie MN 55344-3266

CORRECTION NOTICE - COMPLAINT INSPECTION

RE: 873 SCHEFFER AVE

Dear Property Representative:

A referral has been made to our office regarding code deficiencies that are reported to exist in your building or on the premises. An inspection has not been conducted by the Fire Prevention Division. If these deficiencies do in fact exist, you are hereby notified that the following deficiencies must be corrected immediately. An inspection will be made on January 17, 2018 at 3:00 PM.
DEFICIENCY LIST

1. Garage - NFPA 211 13.2.3 - Immediately discontinue use and remove the wood burning stove from the residential garage.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd,
Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: Justin.Elvestad@ci.stpaul.mn.us or call me at 651-266-8982 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Justin Elvestad
Fire Inspector