



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

We need the following to process your appeal:

- \$25 filing fee (non-refundable) (payable to the City of Saint Paul) (if cash: receipt number 820506)
 - Copy of the City-issued orders/letter being appealed
 - Attachments you may wish to include
 - This appeal form completed
 - Walk-In OR Mail-In
- for abatement orders only: Email OR Fax

HEARING DATE & TIME (provided by Legislative Hearing Office) Tuesday, <u>June 26, 2018</u> Time <u>1:30 PM</u> Location of Hearing: Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1024 Jessie City: ST PAUL State: MN Zip: 55103

Appellant/Applicant: OGBONNA JWU Email onebestcare@gmail.com

Phone Numbers: Business _____ Residence _____ Cell 651-983-1215

Signature: [Handwritten Signature] Date: 6-8-18

Name of Owner (if other than Appellant): _____

Mailing Address if Not Appellant's: _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List/Correction
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other (Fence Variance, Code Compliance, etc.)

I am appealing order to repair driveway parking. The driveway was not paved when I bought the property in 2004. Tenants are not allowed to park there, until it is paved or repaired.



CITY OF SAINT PAUL

375 Jackson Street, Suite 220
St Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-9124
Web: www.stpaul.gov/dsi

May 15, 2018

OGBONNA IWU
PO BOX 14128
ST PAUL MN 55114-0128

CORRECTION NOTICE - RE-INSPECTION COMPLAINT

RE: 1024 JESSIE ST
Ref. # 106298

Dear Property Representative:

A re-inspection was made on your building on January 17, 2018, in response to a complaint. You are hereby notified that the following deficiencies must be corrected prior to re-inspection date.

A re-inspection will be made on June 14, 2018 at 10:30 pm.

Failure to comply may result in a criminal citation or the revocation of the Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

1. Exterior - SPLC 34.08 (7) - All parking spaces shall be paved with asphalt, concrete, or durable dustless surfacing. Before any existing spaces may be paved, site plan approval must be obtained as specified in the St. Paul Zoning Code. Contact DSI Zoning at 651-266-8989. The asphalt driveway has deteriorated and in need of replacement.
2. Interior - Basement - MSBC -Section 105.1 - Permits Required. Any owner or authorized agent who intends to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, the installation of which is regulated by this code, or to cause any such work to be done, shall first make application to the building official and obtain the required permit. Work being done requires a permit. The permit for the hot water heater needs a final inspection and the file closed, contact your contractor to arrange the final inspection. ✓

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: 651-266-8585 and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at brian.schmidt@ci.stpaul.mn.us or call me at 651-266-8981 between 7:30 a.m - 9:00 a.m.

Please help to make Saint Paul a safer city in which to live and work.

Sincerely,

Brian Schmidt
Fire Inspector

Ref. # 106298