

Rick Mack

From: Skradski, John (CI-StPaul) <john.skradski@ci.stpaul.mn.us>
Sent: Friday, May 30, 2014 8:50 AM
To: Rolf Sullivan; Rick Mack
Cc: Bloom, Jim (CI-StPaul); Ubl, Stephen (CI-StPaul); casey@immunize.org; barb@suntide.com
Subject: RE: 2550 University Ave W -- Court International, Immunization Action Coalition Tenant

Rolf,

What we are looking for is the illuminated exit directional signage that will lead the tenant IAC to the exit stairs.

It might be helpful during the rough in inspection to confer with the building inspector for the best locations.

John



John Skradski
Plan Examiner II
Department of Safety and Inspections
375 Jackson Street, Suite 220
Saint Paul, MN 55101
P: 651-266-9075
john.skradski@ci.stpaul.mn.us

The Most Livable
City in America



Making Saint Paul the Most Livable City in America

From: Rolf Sullivan [mailto:rolf@wjrc.com]
Sent: Friday, May 30, 2014 8:32 AM
To: Skradski, John (CI-StPaul); 'Rick Mack'
Cc: Bloom, Jim (CI-StPaul); Ubl, Stephen (CI-StPaul); casey@immunize.org; barb@suntide.com
Subject: RE: 2550 University Ave W -- Court International, Immunization Action Coalition Tenant

John,

Please inform us as to what 'adequate signage' will be approved.

1. Signage type (illuminated exit directional signage, additional instructions/warnings)?
2. Locations.
 - a. Outside of each suite entry with directional arrows (floor, standard vision height, ceiling)?
 - b. Outside of southern stairwell with instructions/warnings not to venture up the north hallway.
 - c. Any additional languages besides English (if written instructions/warnings are required)?

Regards,
Rolf

WJR, Inc.

Architects - Designers
8175-B Lewis Road
Golden Valley, MN 55427

Rolf W. Sullivan
Principal
763-398-0454 (Direct)
763-398-0452 (General)
763-398-0455 (Fax)
rsullivan@wjinc.com

From: Skradski, John (CI-StPaul) [<mailto:john.skradski@ci.stpaul.mn.us>]
Sent: Friday, May 30, 2014 8:19 AM
To: Rolf Sullivan (rolf@wjinc.com); Rick Mack (rick.mack@planforcegroup.com)
Cc: Bloom, Jim (CI-StPaul); Ubl, Stephen (CI-StPaul)
Subject: 2550 University Ave W -- Court International, Immunization Action Coalition Tenant

Rolf and Rick,

Discussed the door in the corridor situation with Building Official Steve Ubl (he used to be the field inspector for this area and is familiar with the building).

He felt it would be best not to install the door in the corridor and instead provide adequate exit signage for the people leaving the tenant space.

Sorry for all the confusion, John



John Skradski
Plan Examiner II
Department of Safety and Inspections
375 Jackson Street, Suite 220
Saint Paul, MN 55101
P: 651-266-9075
john.skradski@ci.stpaul.mn.us

The Most Livable
City in America



Making Saint Paul the Most Livable City in America