

We need the following to process your appeal:

APPLICATION FOR APPEAL

Saint Paul City Council - Legislative Hearings

RECEIVED

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8585

MAR 13 2019

CITY CLERK

\$25 filing fee (non-refundable) (payable to the City of Saint Paul) HEARING DATE & TIME

(if cash: receipt number)	(provided by Legislative Hearing Office)
Copy of the City-issued orders/letter being appealed	Tuesday, March 19, 2019
O Attachments you may wish to include	
This appeal form completed	Time
•	Location of Hearing:
	Room 330 City Hall/Courthouse
for abatement orders only: O Email OR O Fax	
Address Being Appealed:	
Number & Street: 1681 Van Buren ave City: 5	State: MM Zip: 55/104
Appellant/Applicant: Leslie K. Lucht E	mail 6+5/9682083@ Yaha. Con
Phone Numbers: Business <u>6513298483</u> Residence <u>56</u>	
Signature:	Date:
Name of Owner (if other than Appellant):	
Mailing Address if Not Appellant's: 1090 Cumberl	and St St. Pound mn 5577
Phone Numbers: Business 6573298483 Residence	Cell
What Is Being Appealed and Why? Vacate Order/Condemnation/ Comments:	Attachments Are Acceptable N 12Her Lalemarch 11)
Nevocation of the C of O	2019
O Summary/Vehicle Abatement	0017
© Fire C of O Deficiency List/Correction	
O Code Enforcement Correction Notice	
(3)	
O Vacant Building Registration	
Other (Fence Variance, Code Compliance, etc.)	

Ricardo X. Cervantes, Director

SAINT PAUL CITY OF SAINT PAUL

375 Jackson Street, Suite 220 St Paul, Minnesota 55101-1806 Telephone: 651-266-8989 Facsimile: 651-266-9124 Web: www.stpaul.gov/dsi

March 11, 2019

ELIZABETH LUCHT LESLIE K LUCHT 1090 CUMBERLAND ST ST PAUL MN 55117-4869

CORRECTION NOTICE - RE-INSPECTION COMPLAINT

RE: 681 VAN BUREN AVE

Ref. # 106279

Dear Property Representative:

A re-inspection was made on your building on March 11, 2019, in response to a complaint. You are hereby notified that the following deficiencies must be corrected prior to re-inspection date. A reinspection will be made on March 25, 2019 at 10:00AM.

Failure to comply may result in a criminal citation or the revocation of the Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

- 1. Bedroom off the kitchen SPLC 34.10 (7), 34.17 (5) Repair and maintain the ceiling in an approved manner.-Leak from snow on the roof is coming through the ceiling.
- 2. Bedroom off the kitchen; Living Room SPLC 34.09 (4), 34.33 (3) Repair and maintain the window in good condition.-Nails in the window frame prevent the window from being opened.
- 3. Living Room SPLC 34.09 (4), 34.33 (3) Repair and maintain the window glass.-Glass is broken on the inside part of the window in the living room.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

Ricardo X. Cervantes, Director

SAINT PAUL AAAA

CITY OF SAINT PAUL

375 Jackson Street, Suite 220 St Paul, Minnesota 55101-1806 Telephone: 651-266-8989 Facsimile: 651-266-9124 Web: www.stpaul.gov/dsi

March 4, 2019

ELIZABETH LUCHT LESLIE K LUCHT 1090 CUMBERLAND ST ST PAUL MN 55117-4869

CORRECTION NOTICE - RE-INSPECTION COMPLAINT

RE:

681 VAN BUREN AVE

Ref. # 106279

Dear Property Representative:

A re-inspection was made on your building on March 4, 2019, in response to a complaint. You are hereby notified that the following deficiencies must be corrected prior to re-inspection date. A reinspection will be made on March 25, 2019 at 10:00AM.

Failure to comply may result in a criminal citation or the revocation of the Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: 651-266-8585 and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at scott.weeks@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m. - 9:00 a.m.

Please help to make Saint Paul a safer city in which to live and work.

Sincerely,

Scott Weeks Fire Safety Inspector

Ref. # 106279