



# Fire Inspection Report

**City of Saint Paul**  
 Department of Safety and Inspections  
 375 Jackson Street – Suite 220  
 Saint Paul MN 55101-1806

Owner Name Vanquish AP  
 Owner Address 301 4th Ave. S. STE 765  
 City State Zip Minneapolis MN  
 Owner Phone 612-223-7382

License \_\_\_\_\_  
 Complaint \_\_\_\_\_  
 C of O \_\_\_\_\_  
 Date 2-14-19

**Building Address:** 1155 Marion St. Saint Paul MN

You are hereby notified to remedy the conditions stated below immediately. A reinspection will be made after the reinspection date stated below. If you consider any of these code requirements to be unreasonable, you may appeal to the Legislative Hearing Officer. Applications for appeals may be obtained at the City Clerks Office, 310 City Hall 651-266-8585 within 10 days of the date of the original orders.

Code	Conditions to be Corrected
MSFC 603.7	Immediately discontinue use of unsafe heating appliance until repaired or replaced by a licensed contractor. This work may require a permit. Call DSI at 651-266-8989. Red tags may not be removed except by fire department inspectors.
SPLC 34.23	Condemned. Immediately vacate the premises. This property may not be occupied until inspected.

Owner or Representative Signature \_\_\_\_\_

Occupancy Type \_\_\_\_\_ Inspector Signature [Signature] 651-336-8101  
 CFO Key \_\_\_\_\_ Reinspection Date \_\_\_\_\_

\*\* For further information on this report, contact the Fire Inspection Division at 651-266-8989 \*\*