

## Sec. 93.08. - Location of meter.

The meter setting shall be as close as possible to the inside of the foundation wall at the point of entrance of the water service connection, and all piping beyond the meter shall be carried above the basement floor, except that the water utility may permit a special location of the meter, provided in all cases the pipe shall be at a sufficient depth to prevent freezing. Where such permission is granted, the pipe between the point of entrance and the water meter shall be as short as possible and may be run overhead or carried under the concrete floor. If a joint is provided on a copper water service connection under a concrete floor, the copper pipe shall be installed in a schedule 40 poly vinyl chloride (PVC) pipe or other approved equal having a minimum diameter of four (4) inches, laid continuous from a point twenty-four (24) inches outside of the foundation wall to the meter location, shall have tight joints, shall be laid sufficiently straight to permit the installation or withdrawal of the water pipe, and shall be laid to drain to the outside of the foundation wall.

(Code 1956, § 254.10; Ord. No. 16855, 11-19-81; Ord. No. 17001, 2-24-83; C.F. No. 93-905, § 30, 7-15-93)