



CITY OF SAINT PAUL

375 Jackson Street., Suite 220
Saint Paul, MN 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-1919
Web: www.stpaul.gov/dsi

October 4, 2018

Jaime Ramiro Inamagua
15550 Float Lane
Apple Valley MN 55124-6020

Kris Kujala
Paul Scharf
Ramsey County - Tax Forfeit Properties
90 W Plato Blvd
St Paul MN 55107

Order to Abate Nuisance Building(s)

Dear Sir or Madam:

The Vacant/Nuisance Buildings Unit, Department of the Department of Safety and Inspections, Division of Code Enforcement, hereby declares the premises located at:

718 ORANGE AVE E

With the following Historic Preservation information: NONE

and legally described as follows, to wit:

OAK VILLE PARK LOT 5 BLK 9

to comprise a nuisance condition in violation of the Saint Paul Legislative Code, Chapter 45.02, and subject to demolition under authority of Chapter 45.11.

On September 3, 2018 a Building Deficiency Inspection Report was compiled and the following conditions were observed.

This list of deficiencies is not necessarily all the deficiencies present at this time. This building(s) is subject to the restrictions of Saint Paul Ordinance Chapter 33.03 and shall not again be used for occupancy until such time as a Certificate of Compliance or a Certificate of Occupancy has been issued. All repairs must be in accordance with appropriate codes. Changes or additions to the electrical system, mechanical system, or the plumbing system may necessitate updating or upgrading the systems involved.

This is a one and one-half story, wood frame, single-family dwelling with a detached two-stall garage.

The following is excerpted from the November 8, 2017 Code Compliance Report:

BUILDING

1. Insure basement cellar floor is even, is cleanable, and all holes are filled.
2. Install floor covering in bathroom and kitchen that is impervious to water.
3. Repair walls, ceiling and floors throughout, as necessary.
4. Prepare and paint interior and exterior as necessary. Observe necessary abatement procedures (EPA, MPCA and St. Paul Legislative Code, Chapter 34 for additional information) if lead base paint is present.
5. Re-level structure as much as is practical.
6. Where wall and ceiling covering is removed install full thickness or code-specified insulation.
7. Install Smoke Detectors/Carbon Monoxide Detectors per MN Conservation Code and the MN Dept. of Labor and Industry: Install per code where feasible.
8. Provide major clean-up of premises.
9. Install water-proof enclosure in shower area.
10. Repair siding, soffit, fascia, trim, etc. as necessary.
11. Provide proper drainage around house to direct water away from foundation of house.
12. Tuck Point interior/exterior of foundation as necessary.
13. Provide proper drainage around house to direct water away from foundation of garage.
14. Install rain leaders to direct drainage away from foundation.
15. Install flashing in an approved manner at the intersection of the roof with walls, chimneys, and other conjoined surfaces.
16. Provide general rehabilitation of garage.
17. Install address numbers visible from street and on the alley side of garage.
18. Grade must drain away from foundation of dwelling. Maintain 6 inch clearance between wood and soil.
19. Install guardrail on basement stairs.
20. Install safety glass in two windows on stair landings and 1 window at top of basement stairs.
21. Repair or replace kitchen cabinets and sink.
22. Replace missing or damaged down spouts and gutters.
23. Dry out basement and eliminate source of moisture.
24. Replace damaged or missing siding on house and garage.
25. Properly install flashing at roof and wall connection.
26. Replace garage door.
27. Replace damaged or decayed deck framing and deck boards.
28. New roof covering installed without inspections; have inspected to verify installed to code.
29. Remove mold, mildew and moldy or water damaged materials.
30. Repair or Replace any deteriorated window sash, broken glass, sash holders, re-putty, etc as necessary.
31. Provide complete storms and screens, in good repair for all door and window openings.
32. Provide functional hardware at all doors and windows.
33. Repair or replace damaged doors and frames as necessary, including storm doors.
34. Weather seal exterior doors, threshold and weather-stripping.

35. A building permit is required to correct the above deficiencies. All work is to be done in a workmanship like manner.

ELECTRICAL

1. Properly wire microwave/hood fan above range to current NEC.
2. Remove and/or rewire all illegal, improper or hazardous wiring to current NEC.
3. Replace conduit/fittings due to excessive corrosion.
4. No access to garage at time of inspection. Insure garage wired to NEC.
5. Electrical panel removed. Replace with new panel and rewire entire service to current NEC.
6. Ensure/rewire all electrical associated with NM cables to current NEC. An electrical permit was never purchased for that wiring.
7. No power at time of inspection. Test all electrical outlets and ensure all luminaires (light fixtures) are working properly when power is restored.
8. Repair the electrical service grounding conductor to the metallic water piping system. Install a conductor sized to Table 250.66 (NEC) from the electrical service to within 5' of the entrance point of the water service, and bond around the water meter.
9. Provide a complete circuit directory at service panel indicating location and use of all circuits.
10. Properly strap and support cables and/or conduits.
11. Repair or replace all broken, painted over, corroded, missing or loose receptacles, luminaires (light fixtures), switches, covers and plates to current code.
12. Check all receptacles for proper polarity (including 2-prong) and verify ground on 3-prong receptacles. Ensure all GFCI receptacles are functioning properly. Rewire and/or replace receptacles that are improperly wired or not functioning properly.
13. Install hard-wired, battery backup, Carbon Monoxide smoke detector as specified in Chapter 58 of the Saint Paul Legislative Code, and other smoke detectors and carbon monoxide detectors as required by the Minnesota State Building Code.
14. All electrical work must be done by a Minnesota-licensed electrical contractor under an electrical permit.

PLUMBING

1. Basement -Soil and Waste Piping - Install a front sewer clean out.
2. Basement -Soil and Waste Piping - Plug all open piping and properly pitch all piping.
3. Basement -Soil and Waste Piping - Install proper pipe supports.
4. Basement -Soil and Waste Piping - Replace all improper connections, transitions, fittings or pipe usage.
5. Basement -Tub and Shower - Install a proper fixture vent to code.
6. Basement -Tub and Shower - Install the waste piping to code.
7. Basement -Tub and Shower - Install the water piping to code.
8. Basement -Tub and Shower - Repair/replace the fixture that is missing, broken or has parts missing.
9. Basement -Tub and Shower - Install scald and thermal shock protection, ASSE Standard 1016.
10. Basement -Tub and Shower - Replace the waste and overflow.
11. Basement -Water Heater - Correct the pressure and temperature relief valve discharge.
12. Basement -Water Heater - Install the gas shut off and the gas piping to code.

13. Basement -Water Heater - Install the water heater gas venting to code.
14. Basement -Water Heater - The water heater venting requires a chimney liner.
15. Basement -Water Heater -The water heater must be fired and in service.
16. Basement -Water Meter - Raise the water meter to a minimum of 12 inches above the floor.
17. Basement -Water Meter - Support the water meter to code.
18. Basement -Water Meter - The service valves must be functional and installed to code.
19. Basement -Water Meter - Repair the corroded or incorrect water meter piping.
20. Basement -Water Piping - Repair or replace all the corroded, broken, or leaking water piping.
21. Basement -Water Piping - Replace all the improper fittings and fittings that have improper usage.
22. Basement -Water Piping - Provide a one (1) inch water line to the first major take off.
23. Exterior -Lawn Hydrants - The lawn hydrant(s) require a backflow preventer.
24. First Floor -Gas Piping - Install an approved shut off; connector and gas piping for the range.
25. First Floor -Plumbing - General - Remove all unused waste, vent, water and gas piping to the main and cap or plug to code.
26. First Floor -Plumbing - General - Provide proper fixture spacing.
27. First Floor -Sink - Install a proper fixture vent to code.
28. First Floor -Sink - Install the waste piping to code.
29. First Floor -Sink - Install the water piping to code.
30. First Floor -Sink - Repair/replace the fixture that is missing, broken or has parts missing.
31. Second Floor -Lavatory - Install a proper fixture vent to code.
32. Second Floor -Lavatory - Install the waste piping to code.
33. Second Floor -Lavatory - Install the water piping to code.
34. Second Floor -Lavatory - Repair/replace the fixture that is missing, broken or has parts missing.
35. Second Floor -Plumbing - General - Provide a water tight joint between the fixture and the wall or floor.
36. Second Floor -Toilet Facilities - Install a proper fixture vent to code.
37. Second Floor -Toilet Facilities - Install the waste piping to code.
38. Second Floor -Toilet Facilities - Install the water piping to code.
39. Second Floor -Toilet Facilities - Repair/replace the fixture that is missing, broken or has parts missing.
40. All the above corrections to waste, vent, water, and gas piping shall be per the Minnesota Plumbing Code Chapter 4714, Minnesota Rules Chapter 326, 4716, 1300, the Minnesota Mechanical Code, the Minnesota Fuel Gas Code, and Saint Paul Regional Water Services Water Code. All plumbing must be done by a plumbing contractor licensed in the State of Minnesota and the City of St. Paul by a plumber licensed in the State of Minnesota who also possess a City of Saint Paul Competency Card and after obtaining an approved City of Saint Paul Plumbing Permit.

HEATING

1. Clean and Orsat test furnace burner. Check all controls for proper operation. Check furnace heat exchanger for leak; provide documentation from a licensed contractor that the heating unit is safe.

2. Install approved metal chimney liner.
3. Vent clothes dryer to code and provide approved gas piping and valve (plumbing or mechanical gas permit is required).
4. Provide adequate combustion air and support duct to code.
5. Provide support for gas lines to code.
6. Plug, cap and/or remove all disconnected gas lines, non-conforming gas lines and unapproved valves.
7. Bathrooms require a means to ventilate the space. Provide a window with an aggregate glazing area of not less than 3 square feet, one half of which must be operable. Alternative is a bath fan properly vented to the outside. All kitchen exhaust must be venting to exterior. A mechanical ventilation permit will be required for the bath fan and/or kitchen exhaust.
8. Provide all supply and return ducts for warm air heating system must be clean before final approval for occupancy. Documentation is required from a licensed duct-cleaning contractor that the duct system has been cleaned.
9. Repair and/or replace heating registers as necessary.
10. Provide heat in every habitable room and bathrooms.
11. Provide a means of returning air from every habitable room to the furnace. Return air cannot be taken from closets, bathrooms, toilet rooms, kitchen or mechanical rooms.
12. Remove remaining condensing unit and/or AC coil in plenum, drain line and seal all openings (refrigeration permit is required if a new system is to be installed).
13. Run A/C condensate drain three-quarter inch nominal size to an approved location and secure as needed.
14. Unable to gain entry to garage during inspection, however chimney vent is visible through the roof. If there is any nonconforming heating equipment in the garage, remove it and all connecting piping and venting and permanently seal and plug all openings or install equipment to code.
15. Mechanical permits Gas and Warm Air are required for the above work.

As owner, agent or responsible party, you are hereby notified that if these deficiencies and the resulting nuisance condition is not corrected by **November 3, 2018** the Department of Safety and Inspections, Division of Code Enforcement, will begin a substantial abatement process to demolish and remove the building(s). The costs of this action, including administrative costs and demolition costs will be assessed against the property taxes as a special assessment in accordance with law.

As first remedial action, a Code Compliance Inspection Report must be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989. This inspection will identify specific defects, necessary repairs and legal requirements to correct this nuisance condition. You may also be required to post a five thousand dollar (\$5,000.00) performance bond with the Department of Safety and Inspections before any permits are issued, except for a demolition permit. Call the Department of Safety and Inspections for more information at 651-266-8989.

If this building is located in a historic district or site (noted on page 1, above, just below the property address) then you must contact Heritage Preservation (HPC) staff to discuss your proposal for the repairs required by this order and compliance with preservation guidelines. Copies of the guidelines and design review application and forms are available from the

Department of Safety and Inspections web site (see letterhead) and from the HPC staff. No permits will be issued without HPC review and approval. HPC staff also can be reached by calling 651-266-9078.

As an owner or responsible party, you are required by law to provide full and complete disclosure of this "Order to Abate" to all interested parties, all present or subsequent renters and any subsequent owners. The property shall not be sold, transferred or conveyed in any manner until the Nuisance Conditions have been abated and the Certificate of Code Compliance or Certificate of Occupancy has been issued.

The Enforcement Officer is required by law to post a placard on this property which declares it to be a "nuisance condition", subject to demolition and removal by the City. This placard shall not be removed without the written authority of the Department of Safety and Inspections, Division of Code Enforcement. The department is further required to file a copy of this "Order to Abate" with the City Clerk's Office.

If corrective action is not taken within the time specified in this order, the Enforcement Officer will notify the City Council that abatement action is necessary. The City Clerk will then schedule dates for Public Hearings before the City Council at which time testimony will be heard from interested parties. After this hearing the City Council will adopt a resolution stating what action if any, it deems appropriate.

If the resolution calls for abatement action the Council may either order the City to take the abatement action or fix a time within which this nuisance must be abated in accordance with the provisions of Chapter 33 of the Saint Paul Legislative Code and provide that if corrective action is not taken within the specified time, the City shall abate this nuisance. The costs of this action, including administrative costs will be assessed against the property as a special assessment in accordance with law.

If you have any questions or request additional information please contact **Rich Singerhouse** at **651-266-1945**, or you may leave a voicemail message.

Sincerely,

Rich Singerhouse

Vacant Buildings Enforcement Inspector

cc: Legistar Approval list and City Council