



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
Marcia Moermond, Legislative Hearing Officer  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8585 FAX: (651) 266-8574

February 5, 2021

Irine Katras  
1676 White Bear Ave  
St. Paul, MN 55106

VIA EMAIL: [irenexkatras@gmail.com](mailto:irenexkatras@gmail.com)

Re: Appeal for Property at 1676 White Bear Avenue

Dear Ms. Katras:

This is to confirm that on February 2, 2021 at the Legislative Hearing, Marcia Moermond, the Legislative Hearing Officer, recommended that the City Council **grant to March 31, 2021 for installation of stainless steel side panels over the grill hood and installation of additional nozzles in the fire suppression system.** Additionally, **grant to July 1, 2022 for compliance with orders as they relate to gyro machine.** All Interim safety measures, such as turning off machine when not in use and cleaning grease out hourly shall remain in place, and a fire extinguisher must be within 8 feet of gyro machine at all times.

The City Council Public Hearing is scheduled for February 17, 2021 at 3:30 p.m. Due to the COVID-19 pandemic, **we will not be holding hearings in person.** If you are contesting Ms. Moermond's recommendation, you may send written testimony to be added to the record to [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us) or by voicemail at 651-266-6805. If you don't wish to contest, no further action is needed.

If you have any questions, please contact me at 651-266-8515.

Sincerely,  
/s/

Joanna Zimny  
Legislative Hearing Executive Assistant

c:

Fire Supervisors  
James Thomas - Department of Safety & Inspections, Fire Safety Inspector  
Ward 6 – Councilmember Nelsie Yang