



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Telephone: 651-266-9090
Saint Paul, MN 55101-1806

April 23, 2009

MICHAEL F LARSON
995 GRAND AVE APT 101
ST PAUL MN 55105

1128 MACKUBIN ST

Dear Property Representative:

Your building was inspected on April 23, 2009.

The building was found to be unsafe, unfit for human habitation, a public nuisance, a hazard to the public welfare or otherwise dangerous to human life. A Condemnation Placard has been posted on the building.

The following deficiency list must be completed immediately or the building vacated.

CONDEMNATION OF THE BUILDING REVOKES THE FIRE CERTIFICATE OF OCCUPANCY.

Failure to complete the corrections may result in a criminal citation. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy.

DEFICIENCY LIST

1. Interior - SPLC 34.23, MSFC 110.1 - This occupancy is condemned as unfit for human habitation. This occupancy must not be used until re-inspected and approved by this office.-Restore water.
2. Interior - SPLC 34.11(4), 34.34(1) SPC 4715.0200A - Provide an adequate water supply to all water closets, sinks, showers and tubs.-Restore water or vacate.
3. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
4. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the City Clerks Office, Room 310 - City Hall (651-266-8688), 15 Kellogg Boulevard West, and must be filed within 10 days of the date of the original orders.

If you have any questions, you may contact me at 651-266-8988.
Sincerely,

Lisa Martin
Fire Inspector