



# OPTIONS

Date: 6/28/21

Order: SI7187

Customer: PA Veng

Technician: THOMAS

**Observations**

(separate gate)  
 \* Call Genes sewer + water to run new line from street into home + up out of pits. Now I can gate tie into that above 12" AFP/pipe meter / 2 valves / meter couplings (run 1" up wall to over siding tie into main pipe feed to whole house

**Findings**

	MONTHLY OPTIONS OR 18 MONTHS	Regular	TEC
①	Water meter repipe / valves / run 1" over to tee + tie into that feeds home (tie into new pipe from street per other contractor) that specializes in that / mount meter atleast 12" above F.F.	2500	
②	Install 40 gallon Powervent heater / run 2" vent to Southeast window / electric outlet is there. (Pull permit by MSP) 6 yr P/LC warranty (haul away old heater) Repipe gas / valve up high / tee to 3/8" gas to garage line / valve. Run new gas / to heater up to cube / no teflon + test / up vent to chimney in wye feeding for furnaces • Cut out rusty 1/2" copper above heater + repipe • Remove piercing valve above heater	4000	
③	Done basement stairs valve / head - install better single handle stair valve + head - repipe as needed - tie into 1/2" CPVC pipe	1633	
④	Dryer - run new 4" vent + insulate / new dryer wall vent to outside / install new gas valve to dryer / drip leg tee / gas piping to dryer	1080	

Warranty listed is only applicable to specific items repaired and does not cover items not included in the repairs. Warranty does not cover repaired items damaged by fire, flood, lightning, corrosive environments or negligence and does not cover consequential damages from failure of parts.



ALL

OBSERVATIONS

Date: 6/28/21

Order: 517187

Customer: PA VANG

Technician: THOMAS

Observations

- ① Dryer in basement - needs gas valve installed replacing grease valve/tee sediment trap/new copper. New 4" vent + insulate/new exhaust flaps on outside of house.
- ② Water meter in pit - no valves all old lead joints/underground 15' to supply to house  $\frac{3}{4}$ " galv. tee. Needs Genes sewer + water to gate running new water line thru tunnel depending how far they take it - I will gate tie into the new pipe - meter repipe above floor 12" AFP - run 1" across ceiling to main

Findings

monthly options or 18 months REGULAR TCC

- ③ - Basement shower - needs new Delta single handle chrome/shower head/ no tub spout - tie into CPVC pipe  $\frac{1}{2}$ "
- ④ - 40 gallon heater N.V - has chimney liner - but is backdrafting. Teller type on gas fittings - tee picks up gas line that goes to garage water heater. Needs repipe of gas/valve up high than tee to  $\frac{3}{4}$ " line to garage/ new gas piping to heater. They need permit pulled on heater - With backdraft gantly now power vent to cap chimney wye house for furnace / Run 40 gallon Power vent vent to window / weel southeast window / had electric outlet cut out leaky  $\frac{1}{2}$ " pvc above heater / replace Elbow/tee pvc above heater / Permit pulled by MSP.

\* customer has lawsuit going against city / BT said they can pay for work + do work through situation

TCC MEMBERSHIP 08.25 MONTH

Warranty listed is only applicable to specific items repaired and does not cover items not included in the repairs. Warranty does not cover repaired items damaged by fire, flood, lightning, corrosive environments or negligence and does not cover consequential damages from failure of parts.