



## Legislation Details (With Text)

**File #:** RLH FOW      **Version:** 2  
12-234

**Type:** Resolution LH Fire Ordered      **Status:** Passed  
Windows

**In control:** City Council

**Final action:** 7/18/2012

**Title:** Appeal of Shirley M. Thom to a Fire Inspection Correction Notice (windows only) at 1611 TAYLOR AVENUE.

**Sponsors:** Russ Stark

**Indexes:** Fire C of O Letter, Ward - 4, Windows

**Code sections:**

**Attachments:** 1. 1611 Taylor Ave.appeal.6-6-12.pdf, 2. 1611 Taylor Ave.Thom Ltr 6-21-12.pdf

Date	Ver.	Action By	Action	Result
7/24/2012	2	Mayor's Office	Signed	
7/18/2012	2	City Council	Adopted	Pass
6/19/2012	1	Legislative Hearings	Referred	

Appeal of Shirley M. Thom to a Fire Inspection Correction Notice (windows only) at 1611 TAYLOR AVENUE.

We are asking that a variance be granted as the bedroom windows meet the minimum glazed area and width requirement but lack the openable height requirement.

May 29, 2012

Mitchell Imbertson

No hearing necessary.

Yes, 2 rear bedrooms - 8 inches egress opening height and 2 side bedrooms - 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Shirley M. Thom to a Fire Inspection Correction Notice (windows only) at 1611 TAYLOR AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 8-inch variance on the openable height of the egress windows in the two rear bedrooms, and grant a 5-inch variance on the openable height of the egress window in the two side bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.