



## Legislation Details (With Text)

**File #:** RLH FCO 12- **Version:** 2  
317

**Type:** Resolution LH Fire C of O OR **Status:** Passed  
Correction Order

**In control:** City Council

**Final action:** 8/1/2012

**Title:** Appeal of Gerald Yost to a Fire Inspection Correction Notice at 2142 PALACE AVENUE.

**Sponsors:** Chris Tolbert

**Indexes:** Fire C of O Letter, Ward - 3

**Code sections:**

**Attachments:** 1. 2142 Palace.appeal.5-11-12, 2. 2142-2146 Palace Ave.Yost Ltr 7-11-12.pdf

Date	Ver.	Action By	Action	Result
8/8/2012	2	Mayor's Office	Signed	
8/1/2012	2	City Council	Adopted	Pass
7/10/2012	1	Legislative Hearings	Referred	
6/5/2012	1	Legislative Hearings	Laid Over	

Appeal of Gerald Yost to a Fire Inspection Correction Notice at 2142 PALACE AVENUE.

Fuel oil tank

May 3, 2012

Jay Bohan

WHEREAS, in the matter of the Appeal of Gerald Yost to a Fire Inspection Correction Notice at 2142 PALACE AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal and grant an extension for one year to comply with the gas tank by either 1) removing the tank, or 2) having the tank emptied and cleaned by licensed contractors. The tank should also be rendered unusable by drilling a hole in its side capping fill-line on the tank and the fill-line leading into the house; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.