



## Legislation Details (With Text)

**File #:** RLH WP 12- 75 **Version:** 2

**Type:** Resolution LH Window Permit **Status:** Archived  
**In control:** Legislative Hearings  
**Final action:** 8/1/2012

**Title:** Appeal of Daniel Schmidt, on behalf of Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 878 FREEMONT AVENUE.

**Sponsors:** Kathy Lantry

**Indexes:** Ward - 7, Windows

**Code sections:**

**Attachments:** 1. 878 Fremont Ave.appeal.6-20-12, 2. 878 Fremont Ave.Public Health Ltr 7-10-12.pdf

Date	Ver.	Action By	Action	Result
7/10/2012	1	Legislative Hearings	Referred	

Appeal of Daniel Schmidt, on behalf of Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 878 FREEMONT AVENUE.

Windows

June 20, 2012

No hearing necessary.

Yes, 3 incghes egress opening width.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, on behalf of Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 878 FREEMONT AVENUE the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable width of the double hung replacement egress bedroom windows measuring 24 inches high by 17 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.