



Legislation Details (With Text)

File #: RLH WP 11- 29 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 7/6/2011

Title: Appeal of Window World, on behalf of Norm Lee, to an Egress Window Non-Compliance Determination at 1311 CLARENCE STREET.

Sponsors: Dan Bostrom

Indexes: Ward - 6, Windows

Code sections:

Attachments: 1. 1311 Clarence.appeal.5-31-11.pdf, 2. 1311 Clarence St.Window World Ltr 6-14-11.pdf

Date	Ver.	Action By	Action	Result
7/11/2011	2	Mayor's Office	Signed	
7/6/2011	2	City Council	Adopted	Pass
6/14/2011	1	Legislative Hearings	Referred	

Appeal of Window World, on behalf of Norm Lee, to an Egress Window Non-Compliance Determination at 1311 CLARENCE STREET.

Asking for variance on windows.

April 22, 2011

Yes, 10 inches in sill height requirement, if 2 steps of standard dimensions are installed for the full length of the glazed area.

WHEREAS, in the matter of the appeal of Window World, on behalf of Norm Lee, to an Egress Window Non-Compliance Determination at 1311 CLARENCE STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal provided two steps of standard dimensions are installed to address the sill height issue; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.