



Legislation Details (With Text)

File #: RLH WP 12-1 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 2/1/2012
Title: Appeal of Daniel Schmidt, on behalf of the Department of Public Health, to an Egress Window Non-Compliance Determination at 900 CASE AVENUE.
Sponsors: Dan Bostrom
Indexes: Ward - 6, Windows
Code sections:
Attachments: 1. 900 Case.appeal .12-15.11.pdf, 2. 900 Case Ave.Public Health.1-5-12.pdf

Date	Ver.	Action By	Action	Result
2/7/2012	2	Mayor's Office	Signed	
2/1/2012	2	City Council	Adopted	Pass
1/3/2012	1	Legislative Hearings	Referred	

Appeal of Daniel Schmidt, on behalf of the Department of Public Health, to an Egress Window Non-Compliance Determination at 900 CASE AVENUE.

Egress Windows

December 15, 2011

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of the Department of Public Health (Daniel Schmidt) to an Egress Window Non-Compliance Determination at 900 CASE AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of one double hung replacement egress bedroom window measuring 20 inches height by 24 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.