



## Legislation Details (With Text)

**File #:** RLH FOW 11- **Version:** 2  
102

**Type:** Resolution LH Fire Ordered **Status:** Passed  
Windows

**In control:** City Council

**Final action:** 8/17/2011

**Title:** Appeal of Ignatius Kadoma to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1739 FIFTH STREET EAST.

**Sponsors:** Kathy Lantry

**Indexes:** Fire C of O Letter, Ward - 7, Windows

**Code sections:**

**Attachments:** 1. 1739 5th.appeal. 7-12-11.pdf, 2. 1739 Fifth St E.Kadoma Ltr 7-26-11.pdf

Date	Ver.	Action By	Action	Result
8/23/2011	2	Mayor's Office	Signed	
8/17/2011	2	City Council	Adopted	Pass
7/26/2011	1	Legislative Hearings	Referred	

Appeal of Ignatius Kadoma to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1739 FIFTH STREET EAST.

Attic: Required 24" open height X 20" open width; I have 19" open height X 27" open width

June 30, 2011

Yes, 5 inches in openable height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Ignatius Kadoma to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1739 FIFTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress window in the attic; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.