



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
13-5

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 3/20/2013

Title: Appeal of Roseanne Wynn to an Egress Window Non-Compliance Determination at 1415 MARGARET STREET.

Sponsors: Kathy Lantry

Indexes: Ward - 7, Windows

Code sections:

Attachments: 1. 1415 Margaret St.appeal.2-22-13, 2. 1415 Margaret St.Wynn Ltr.3-7-13

Date	Ver.	Action By	Action	Result
3/25/2013	2	Mayor's Office	Signed	
3/20/2013	2	City Council	Adopted	Pass
3/5/2013	1	Legislative Hearings	Referred	

Appeal of Roseanne Wynn to an Egress Window Non-Compliance Determination at 1415 MARGARET STREET.

See Correction Notice. I am asking for a variance.

February 7, 2013

James Perucca

No hearing necessary.

Yes, 5 inches egress opening height for main level northeast and southeast bedrooms.

WHEREAS, in the matter of the Appeal of Roseanne Wynn to an Egress Window Non-Compliance Determination at 1415 MARGARET STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress window in the main level bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.