



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
7

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 5/18/2011

Title: Appeal of Joe Palen to a Fire Inspection Correction Notice at 1505 OLD HUDSON ROAD.

Sponsors: Kathy Lantry

Indexes: Fire C of O Letter, Ward - 7, Windows

Code sections:

Attachments: 1. 1505 Old Hudson.appeal.4-19-11.pdf, 2. 1505 Old Hudson Rd.Palen Ltr 4-19-11.pdf, 3. 1505 Old Hudson Rd.Palen Ltr 4-26-11.pdf

Date	Ver.	Action By	Action	Result
5/31/2011	2	Mayor's Office	Signed	
5/18/2011	2	City Council	Adopted	
4/26/2011	1	Legislative Hearings	Referred	
4/19/2011	1	Legislative Hearings	Laid Over	

Appeal of Joe Palen to a Fire Inspection Correction Notice at 1505 OLD HUDSON ROAD.

Purchased home last year and it had new windows. The egress is not quite big enough. Windows are new. We could build a platform to code to make distance from floor to sill code.

March 29, 2011

WHEREAS, in the matter of the appeal of Joe Palen to a Fire Inspection Correction Notice at 1505 OLD HUDSON ROAD; and

WHEREAS, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal on the window and sill height and grant an extension for 90 days to come into compliance. The appellant must install a step full width (9-10" inch length, 11 inch depth) below the egress bedroom window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.