



Legislation Details (With Text)

File #: RLH WP 11- 30 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 7/6/2011

Title: Appeal of Renewal by Andersen, on behalf of Roger Krenner, to an Egress Window Non-Compliance Determination at 1061 PLEASANT AVENUE.

Sponsors: Dave Thune

Indexes: Ward - 2, Windows

Code sections:

Attachments: 1. 1061 Pleasant.appeal.6-3-11.pdf

Date	Ver.	Action By	Action	Result
7/11/2011	2	Mayor's Office	Signed	
7/6/2011	2	City Council	Adopted	Pass
6/21/2011	1	Legislative Hearings	Referred	

Appeal of Renewal by Andersen, on behalf of Roger Krenner, to an Egress Window Non-Compliance Determination at 1061 PLEASANT AVENUE.

We are appealing 6 replacement windows that will not comply w/St. Paul egress policy. The current windows are short by no more than 6" in height and are compliant w/minimal allowed width. Please approve.

May 31, 2011

Yes, 2 inches in the egress height requirement. No hearing necessary.

WHEREAS, in the matter of the appeal of Renewal by Andersen, on behalf of Roger Krenner, to an Egress Window Non-Compliance Determination at 1061 PLEASANT AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of two double hung replacement egress bedroom windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.