



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
13-9

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 9/4/2013

Title: Appeal of Julie Peterson to a Fire Certificate of Occupancy Correction Notice at 1447 WHITE BEAR AVENUE NORTH.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6

Code sections:

Attachments: 1. 1447 WhiteBear Ave N.appeal.8-20-13, 2. 1447 White Bear Ave N.Peterson Ltr.8-22-13

Date	Ver.	Action By	Action	Result
9/9/2013	2	Mayor's Office	Signed	
9/4/2013	2	City Council	Adopted	Pass
8/20/2013	1	Legislative Hearings	Referred	

Appeal of Julie Peterson to a Fire Certificate of Occupancy Correction Notice at 1447 WHITE BEAR AVENUE NORTH.

We have an older house and would like our upper bedrom window dimensions to be accepted so that foster care children may occupy those rooms. Currently, they are 19" high by 24" wide.

July 26, 2013

James Perucca

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Julie Peterson to a Fire Certificate of Occupancy Correction Notice at 1447 WHITE BEAR AVENUE NORTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress windows in the upper east and southside bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.