



## Legislation Details (With Text)

**File #:** RLH FOW      **Version:** 2  
12-96

**Type:** Resolution LH Fire Ordered      **Status:** Passed  
Windows

**In control:** City Council

**Final action:** 4/4/2012

**Title:** Appeal of Saint Paul Public Housing Agency to a Fire Certificate of Occupancy Inspection Correction Notice at 1570 CHAMBER STREET.

**Sponsors:** Dan Bostrom

**Indexes:** Fire C of O Letter, Ward - 6, Windows

**Code sections:**

**Attachments:** 1. 1570 Chamber.appeal.3-2-13.pdf, 2. 1570 Chamber St.Swanson-PHA Ltr.3-12-12.pdf

Date	Ver.	Action By	Action	Result
4/10/2012	2	Mayor's Office	Signed	
4/4/2012	2	City Council	Adopted	Pass
3/13/2012	1	Legislative Hearings	Referred	

Appeal of Saint Paul Public Housing Agency to a Fire Certificate of Occupancy Inspection Correction Notice at 1570 CHAMBER STREET.

#1 Bedroom - Request variance on openable width.

February 24, 2012

Mike Cassidy

Hearing necessary, unless owner can demonstrate window opens to a width of 16 inches.

WHEREAS, in the matter of the Appeal of Saint Paul Public Housing Agency to a Fire Certificate of Occupancy Inspection Correction Notice at 1570 CHAMBER STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an 8-inch variance egress opening height for the northwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.