



Legislation Details (With Text)

File #: RLH WP 11- 93 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 11/16/2011

Title: Appeal of Larry Columbus, Columbus Exteriors, to an Egress Window Non-Compliance Determination at 570 IGLEHART AVENUE.

Sponsors: Melvin Carter III

Indexes: Ward - 1, Windows

Code sections:

Attachments: 1. 570 Iglehart.appeal.10-25-11.pdf, 2. 570 Iglehart Ave.Ltr 10-25-11.pdf

Date	Ver.	Action By	Action	Result
11/22/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
10/25/2011	1	Legislative Hearings	Referred	

Appeal of Larry Columbus, Columbus Exteriors, to an Egress Window Non-Compliance Determination at 570 IGLEHART AVENUE.

Egress window non-compliance

August 17, 2011

Yes, 2 inches in egress opening width. No hearing necessary.

WHEREAS, in the matter of the Appeal of Larry Columbus, Columbus Exteriors, to an Egress Window Non-Compliance Determination at 570 IGLEHART AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable width of five double hung replacement egress bedroom windows measuring 42 inches high by 18 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.