



Legislation Details (With Text)

File #: RLH FCO 11- **Version:** 2
8

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 5/18/2011

Title: Appeal of Zoua Lo to a Fire Inspection Correction Notice at 1800 WILSON AVENUE.

Sponsors: Kathy Lantry

Indexes: Fire C of O Letter, Ward - 7, Windows

Code sections:

Attachments: 1. 1800 Wilson.appeal.3-31-11.pdf, 2. 1800 Wilson Ave.Lo Ltr 4-12-11.pdf, 3. 1800 Wilson Ave.Lo Ltr 4-26-11.pdf, 4. 1800 Wilson Ave.Lo Ltr 5-5-11.pdf

Date	Ver.	Action By	Action	Result
4/2/2014	2	Mayor's Office	Signed	
5/18/2011	2	City Council	Adopted	
4/26/2011	1	Legislative Hearings	Referred	
4/12/2011	1	Legislative Hearings	Laid Over	

Appeal of Zoua Lo to a Fire Inspection Correction Notice at 1800 WILSON AVENUE.

Item 1 - Windows meet the requirements
Item 4 - Need more time, cold and snow is in the way
Item 6 - More time

March 3, 2011

Recommend variance on egress window dimension, hearing on the rest.

WHEREAS, in the matter of the appeal of Zoua Lo to a Fire Inspection Correction Notice at 1800 WILSON AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council 1) grant an extension to July 1, 2011 to repair the foundation for the porch and sidewalk and 2) grant an 8 inch variance on the height of the egress window opening; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.