



Legislation Details (With Text)

File #: RLH WP 11- 107 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 12/7/2011

Title: Appeal of A Pane in the Glass Construction LLC, on behalf of Angela Polacek, to an Egress Window Non-Compliance Determination at 2248 MATTERHORN LANE.

Sponsors: Kathy Lantry

Indexes: Ward - 7, Windows

Code sections:

Attachments: 1. 2248 Matterhorn.appeal.10-31-11.pdf, 2. 2248 Matterhorn Ln.A Pane in Glass Ltr 11-8-11.pdf

Date	Ver.	Action By	Action	Result
12/13/2011	2	Mayor's Office	Signed	
12/7/2011	2	City Council	Adopted	Pass
11/8/2011	1	Legislative Hearings	Referred	

Appeal of A Pane in the Glass Construction LLC, on behalf of Angela Polacek, to an Egress Window Non-Compliance Determination at 2248 MATTERHORN LANE.

Different opening measurements than required.

October 31, 2011

DD

No hearing necessary.

Yes, 3-inches in egress opening width.

WHEREAS, in the matter of A Pane in the Glass Construction LLC, on behalf of Angela Polacek, to an Egress Window Non-Compliance Determination at 2248 MATTERHORN LANE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable width of one 2-lite slider egress bedroom windows measuring 38.25 inches high by 17.125 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.