



Legislation Details (With Text)

File #: RLH FCO 11- **Version:** 2
303

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 10/5/2011

Title: Appeal of Jayant Saraph to a Fire Certificate of Occupancy Inspection Correction Notice at 601 CLIFFORD STREET.

Sponsors: Russ Stark

Indexes: Fire C of O Letter, Ward - 4, Windows

Code sections:

Attachments: 1. 601 Clifford.appeal.8-9-11.pdf, 2. 601 Clifford St.Saraph Ltr 8-29-11.pdf, 3. 601 Clifford.Photo.pdf, 4. 601 Clifford St.Saraph Ltr 10-3-11.pdf, 5. 601 Clifford St.Revised Ltr 10-3-11.pdf, 6. 601 Clifford.Building Permit.5-25-11.pdf

Date	Ver.	Action By	Action	Result
10/11/2011	2	Mayor's Office	Signed	
10/5/2011	2	City Council	Adopted	Pass
9/13/2011	1	Legislative Hearings	Referred	
8/23/2011	1	Legislative Hearings	Laid Over	
8/16/2011	1	Legislative Hearings	Laid Over	

Appeal of Jayant Saraph to a Fire Certificate of Occupancy Inspection Correction Notice at 601 CLIFFORD STREET.

- #4 - Previously paved inspection
- #7 - Spoke to zoning before installation

August 3, 2011

WHEREAS, in the matter of the Appeal of Jayant Saraph to a Fire Certificate of Occupancy Inspection Correction Notice at 601 CLIFFORD STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal on the sill height of the awning style bedroom windows; appellant will install a bench full width of the windows, and grant a variance on the double hung window in the rear bedroom, upper unit, if the appellant can demonstrate it can be opened to 16 inches; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.