



Legislation Details (With Text)

File #: RLH FCO 11- **Version:** 2
99

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 5/18/2011

Title: Appeal of Robert Bray to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 2068 SUBURBAN AVENUE.

Sponsors: Kathy Lantry

Indexes: Fire C of O Letter, Ward - 7, Windows

Code sections:

Attachments: 1. 2068 Suburban.appeal.3-14-11.pdf, 2. 2068 Suburban Ave.Photo.pdf, 3. 2068 Suburban Ave.Bray Ltr 4-19-11.pdf

Date	Ver.	Action By	Action	Result
4/2/2014	2	Mayor's Office	Signed	
5/18/2011	2	City Council	Adopted	
4/19/2011	1	Legislative Hearings	Referred Under Master Resolution	
4/12/2011	1	Legislative Hearings	Laid Over	
4/5/2011	1	Legislative Hearings	Laid Over	

Appeal of Robert Bray to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 2068 SUBURBAN AVENUE.

My windows in the bedroom are the windows that came with the house.
15.5h X 37w openable
32h X 34w glazed
Inspector asked me to complete this form for a variance.

February 4, 2011

WHEREAS, in the matter of the appeal of Robert Bray to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 2068 SUBURBAN AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an 8-inch variance on the openable height of the egress windows in the main floor northeast, southeast, and southwest bedrooms; now, therefore, be it

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.