



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 3
167

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 10/19/2011

Title: Appeal of Mark Syrstad to a Fire Certificate of Occupancy Inspection Correction Notice at 1121 EARL STREET.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1121 Earl.appeal.9-20-11.pdf, 2. 1121 Earl St.Syrstad ltr 10-7-11.pdf

Date	Ver.	Action By	Action	Result
10/21/2011	3	Mayor's Office	Signed	
10/19/2011	2	City Council	Adopted As Amended	Pass
10/4/2011	1	Legislative Hearings	Referred	

Appeal of Mark Syrstad to a Fire Certificate of Occupancy Inspection Correction Notice at 1121 EARL STREET.

Window has been repaired and now opens and can stay open. This window has been in use since we purchased the property. It was approved per code at that time.

September 8, 2011

Amended 10/19/11

WHEREAS, in the matter of the Appeal of Mark Syrstad to a Fire Certificate of Occupancy Inspection Correction Notice at 1121 EARL STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council ~~deny the appeal~~ grant a 3-inch variance on the openable height of the egress window in the the east bedroom on the 2nd floor; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.