



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
195

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 11/16/2011

Title: Appeal of Victor Hanson to a Fire Certificate of Occupancy Correction Notice at 1538 GRANTHAM STREET.

Sponsors: Russ Stark

Indexes: Fire C of O Letter, Ward - 4, Windows

Code sections:

Attachments: 1. 1538 Grantham.appeal.10-10-11.pdf, 2. 1538 Grantham St.Hanson Ltr 10-20-11.pdf, 3. 1538 Grantham St.Hanson Ltr 11-3-11.pdf

Date	Ver.	Action By	Action	Result
11/23/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
10/25/2011	1	Legislative Hearings	Referred	

Appeal of Victor Hanson to a Fire Certificate of Occupancy Correction Notice at 1538 GRANTHAM STREET.

We are doing replacement windows on the house. The two we want to appeal meet the Building Code but not St. Paul Fire Code. They are cost prohibitive by having to open walls and frame new headers. We are hoping these can stay double hung like the rest are.

October 7, 2011

Yes, 0.31 sqare foot variance in egress opening size. No hearing necessary.

WHEREAS, in the matter of the Appeal of Victor Hanson to a Fire Certificate of Occupancy Correction Notice at 1538 GRANTHAM STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellent; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a .31 square foot variance on the glazed area and a 1-inch variance on the openable height of two double hung replacement egress bedroom windows measuring at 23.59 inches high by 28.56 wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.