



Legislation Details (With Text)

File #: RLH WP 12- 61 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 7/18/2012
Title: Appeal of Molly McGrane, on behalf of Window World, to an Egress Window Non-Compliance Determination at 1631 BIRMINGHAM STREET.
Sponsors: Dan Bostrom
Indexes: Ward - 6, Windows
Code sections:
Attachments: 1. 1631 Birmingham St.appeal.6-01-12, 2. 1631 Birmingham St.Window World Ltr 6-21-12.pdf

Date	Ver.	Action By	Action	Result
7/24/2012	2	Mayor's Office	Signed	
7/18/2012	2	City Council	Adopted	Pass
6/19/2012	1	Legislative Hearings	Referred	

Appeal of Molly McGrane, on behalf of Window World, to an Egress Window Non-Compliance Determination at 1631 BIRMINGHAM STREET.

Windows

May 8, 2012

David Nelson

WHEREAS, in the matter of the Appeal of Molly McGrane, on behalf of Window World, to an Egress Window Non-Compliance Determination at 1631 BIRMINGHAM STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny a variance on the awning egress window replacement measuring 12 inches high by 40 inches wide; and deny a variance on the sill height issue; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.