



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-114

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 5/2/2012

Title: Appeal of Equitron Holdings LLC to an Egress Window Non-Compliance Determination at 1186 SAINT PAUL AVENUE.

Sponsors: Chris Tolbert

Indexes: Fire C of O Letter, Ward - 3, Windows

Code sections:

Attachments: 1. 1186 St. Paul Ave.appeal.3-28-12

Date	Ver.	Action By	Action	Result
5/7/2012	2	Mayor's Office	Signed	
5/2/2012	2	City Council	Adopted	Pass
4/10/2012	1	Legislative Hearings	Referred	

Appeal of Equitron Holdings LLC to an Egress Window Non-Compliance Determination at 1186 SAINT PAUL AVENUE.

Was approved by prior inspection (had to cut windowsill)

March 22, 2012

Rick gavin

No hearing necessary.

Yes, 4 inches egress opening height. Orders were not necessary for a window of this dimension.

WHEREAS, in the matter of the Appeal of Equitron Holdings LLC to an Egress Window Non-Compliance Determination at 1186 SAINT PAUL AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance in egress opening height for the listed windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.