



Legislation Details (With Text)

File #: RLH WP 11- 103 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 12/7/2011
Title: Appeal of Richard Kedrowski to an Egress Window Non-Compliance Determination at 1190 MAGNOLIA AVENUE EAST.
Sponsors: Dan Bostrom
Indexes: Ward - 6, Windows
Code sections:
Attachments: 1. 1190 Magnolia.appeal.10-25-11.pdf, 2. 1190 Magnolia Ave E.Kedrowski Ltr 11-8-11.pdf, 3. 1190 Magnolia Ave E.Revised Kedrowski Ltr 11-8-11.pdf

Date	Ver.	Action By	Action	Result
12/13/2011	2	Mayor's Office	Signed	
12/7/2011	2	City Council	Adopted	Pass
11/8/2011	1	Legislative Hearings	Referred	

Appeal of Richard Kedrowski to an Egress Window Non-Compliance Determination at 1190 MAGNOLIA AVENUE EAST.

Egress window non-compliance

October 25, 2011

DD

No hearing necessary.

Yes, 1 inch in egress opening height.

WHEREAS, in the matter of the Appeal of Richard Kedrowski to an Egress Window Non-Compliance Determination at 1190 MAGNOLIA AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of two slider replacement egress bedroom windows measuring 23.6 inches high by 20.65 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.