



## Legislation Details (With Text)

**File #:** RLH WP 12- 56 **Version:** 2

**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 7/3/2012

**Title:** Appeal of Saint Paul Ramsey County Department of Public Health to an Egress Window Non-Compliance Determination at 1370 SHELDON STREET.

**Sponsors:** Russ Stark

**Indexes:** Ward - 4, Windows

**Code sections:**

**Attachments:** 1. 1370 Sheldon.appeal.5-29-12.pdf

Date	Ver.	Action By	Action	Result
7/9/2012	2	Mayor's Office	Signed	
7/3/2012	2	City Council	Adopted	Pass
6/12/2012	1	Legislative Hearings	Referred	

Appeal of Saint Paul Ramsey County Department of Public Health to an Egress Window Non-Compliance Determination at 1370 SHELDON STREET.

[Enter the Reason for the Appeal]

May 29, 2012

No hearing necessary.

Yes, 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of Saint Paul Ramsey County Department of Public Health to an Egress Window Non-Compliance Determination at 1370 SHELDON STREET ;the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of one double hung replacement egress bedroom window measuring 21-1/4 inches high by 28 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.