



Legislation Details (With Text)

File #: RLH WP 11- 50 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 9/7/2011

Title: Appeal of Derek Tanbeg for The Window Store Home Improvement, on behalf of John Goolshy, to an Egress Window Non-Compliance Determination at 607 ALDINE STREET.

Sponsors: Russ Stark

Indexes: Ward - 4, Windows

Code sections:

Attachments: 1. 607 Aldine.appeal.7-25-11.pdf

Date	Ver.	Action By	Action	Result
9/9/2011	2	Mayor's Office	Signed	
9/7/2011	2	City Council	Adopted	Pass
8/9/2011	1	Legislative Hearings	Referred	

Appeal of Derek Tanbeg for The Window Store Home Improvement, on behalf of John Goolshy, to an Egress Window Non-Compliance Determination at 607 ALDINE STREET.

Nothing indicated

July 21, 2011

Yes, 5 inches in height of egress opening.

WHEREAS, in the matter of the appeal of Derek Tanbeg for The Window Store Home Improvement, on behalf of John Goolshy, to an Egress Window Non-Compliance Determination at 607 Aldine Street, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of one double hung replacement egress window measuring 19.93 inches high by 29.34 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.