



Legislation Details (With Text)

File #: ALH 10-139 **Version:** 1
Type: Appeal-Legislative Hearing **Status:** Filed
In control: Legislative Hearings
Final action: 9/28/2010
Title: Appeal of John Fahey to a Fire Inspection Order at 967 Burns Avenue. (Ward 7)
Sponsors: Kathy Lantry
Indexes: Fire C of O Letter, Ward - 7, Windows
Code sections:
Attachments: 1. 967 Burns Ave.Fire Inspection Ltr.9-10-10, 2. 967 Burns Ave.Appeal.9-17-10.pdf, 3. 967 Burns Ave.PC Ltr 9-28.pdf

Date	Ver.	Action By	Action	Result
9/28/2010	1	Legislative Hearings	Referred Under Master Resolution	

Appeal of John Fahey to a Fire Inspection Order at 967 Burns Avenue. (Ward 7)

One bedroom opens 20" high. Note: paint issue is being appealed. rrn 9/24/10.

September 10, 2010

September 28, 2010

[Enter Summary Here]

Grant an 8-inch variance on the openable height of the egress window in bedroom one; grant a 2-inch variance on the openable height of the egress window in bedroom two. Deny the appeal of the order to paint interior walls and ceilings