



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-141

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 5/16/2012

Title: Appeal of Andy Hybben to a Fire Inspection Correction Notice at 625 SHERWOOD AVENUE.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 625 Sherwood.appeal.4-16-12, 2. 625 Sherwood Ave.Hybben Ltr 4-26-12.pdf

Date	Ver.	Action By	Action	Result
5/18/2012	2	Mayor's Office	Signed	
5/16/2012	2	City Council	Adopted	Pass
4/24/2012	1	Legislative Hearings	Referred	

Appeal of Andy Hybben to a Fire Inspection Correction Notice at 625 SHERWOOD AVENUE.

Northwest and southwest bedroom windows

March 28, 2012

Mike Cassidy

No hearing necessary.

Yes, 7.5 inches egress opening height for the northwest bedroom. Yes, 4 inches egress opening height for the southwest bedroom. ORDERS WERE NOT NECESSARY FOR THE SOUTHWEST BEDROOM, GIVEN ITS DIMENSIONS.

WHEREAS, in the matter of the Appeal of Andy Hybben to a Fire Inspection Correction Notice at 625 SHERWOOD AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7.5-inch variance on the openable height of the egress window in the northwest bedroom and grant a 4-inch variance on the openable height of the egress window in the southwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.