



## Legislation Details (With Text)

**File #:** RLH WP 11- 98 **Version:** 2  
**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 12/7/2011  
**Title:** Appeal of Ted Ryden to an Egress Window Non-Compliance Determination at 1011 MATILDA STREET.  
**Sponsors:** Lee Helgen  
**Indexes:** Ward - 5, Windows  
**Code sections:**  
**Attachments:** 1. 1011 Matililda.appeal.10-19-11.pdf, 2. 1011 Matilda St.Ryden Ltr 11-8-11.pdf

Date	Ver.	Action By	Action	Result
12/13/2011	2	Mayor's Office	Signed	
12/7/2011	2	City Council	Adopted	Pass
11/8/2011	1	Legislative Hearings	Referred	

Appeal of Ted Ryden to an Egress Window Non-Compliance Determination at 1011 MATILDA STREET.

None listed

Yes, 1/2 inch variance in egress opening width.

**DSI staff:** There is no staff signature on the form. Also, 1/2 inch seems extremely picky and punitive for the issuance of this permit.

WHEREAS, in the matter of the Appeal of Ted Ryden to an Egress Window Non-Compliance Determination at 1011 MATILDA STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a .5-inch variance on the openable width of one 2-section sliders replacement egress bedroom window measuring 36-9/16 inches high by 19.5 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.