



## Legislation Details (With Text)

**File #:** RLH FCO 11- **Version:** 2  
90

**Type:** Resolution LH Fire C of O OR **Status:** Passed  
Correction Order

**In control:** City Council

**Final action:** 6/15/2011

**Title:** Appeal of Cheri Kappas to a Fire Inspection Correction Notice at 241 SEVENTH STREET EAST.  
(Laid over from May 18)

**Sponsors:** Dave Thune

**Indexes:** Fire C of O Letter, Ward - 2

**Code sections:**

**Attachments:** 1. 241 7th St E.Appeal.1-31-11.pdf, 2. 241 Seventh St E.Kappas ltr 2-15-11.pdf, 3. 241 Seventh St E.Kappas ltr 3-1-11.pdf, 4. 241 Seventh St E.Kappas ltr 3-8-11.pdf, 5. 241 Seventh St E.Kappas ltr 4-12-11.pdf, 6. 241 Seventh St.Floor plan and Code.pdf, 7. 241 Seventh St.PO floor plan.pdf, 8. 241 Seventh St E.Kappas ltr 4-29-11.pdf

Date	Ver.	Action By	Action	Result
6/20/2011	2	Mayor's Office	Signed	
6/15/2011	2	City Council	Adopted	Pass
5/24/2011	1	Legislative Hearings	Referred	
5/18/2011	1	City Council	Referred	
4/12/2011	1	Legislative Hearings	Referred	
3/8/2011	1	Legislative Hearings		
3/1/2011	1	Legislative Hearings	Laid Over	
2/15/2011	1	Legislative Hearings	Laid Over	

Appeal of Cheri Kappas to a Fire Inspection Correction Notice at 241 SEVENTH STREET EAST. (Laid over from May 18)

Door requirements and range

January 20, 2011

5/24/11 - Grant the appeal on the panic release hardware with signage, grant the hood based on signage, and deny the door swing

4/26/11 - Appeal denied and granted until August 1, 2011 to bring the rear door into compliance.

3/08/11 - Appeal denied on vent hood and granted four months to complete the work;  
Inspector to verify the measurement and occupancy load of the bar space to determine the appropriate door locks that will be required.

Appeal denied on kitchens screen door. All doors must swing in the direction of travel outward.

WHEREAS, in the matter of the appeal of the appeal of Cheri Kappas to a Fire Inspection Correction Notice at 241 SEVENTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal on the panic release hardware with signage, grant the hood based on signage, and deny the door swing; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.