



## Legislation Details (With Text)

**File #:** RLH FOW      **Version:** 2  
12-107

**Type:** Resolution LH Fire Ordered      **Status:** Passed  
Windows

**In control:** City Council

**Final action:** 4/18/2012

**Title:** Appeal of Bruce Hoffmann to a Fire Certificate of Occupancy Inspection Correction Notice at 1945 HAWTHORNE AVENUE EAST.

**Sponsors:** Dan Bostrom

**Indexes:** Fire C of O Letter, Ward - 6, Windows

**Code sections:**

**Attachments:** 1. 1945 Hawthorne.appeal.3-21-12.pdf, 2. 1945 Hawthorne Ave E.Hoffman Ltr.3-26-12.pdf

Date	Ver.	Action By	Action	Result
4/25/2012	2	Mayor's Office	Signed	
4/18/2012	2	City Council	Adopted	
3/27/2012	1	Legislative Hearings	Referred	

Appeal of Bruce Hoffmann to a Fire Certificate of Occupancy Inspection Correction Notice at 1945 HAWTHORNE AVENUE EAST.

Openable height is 22" and width is 27".

March 6, 2012

James Thomas

No hearing necessary.

Yes, 2 inches egress opening height for the attic window. (Orders were not necessary for windows of these dimensions.)

WHEREAS, in the matter of the Appeal of Bruce Hoffmann to a Fire Certificate of Occupancy Inspection Correction Notice at 1945 HAWTHORNE AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in the attic bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.