



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
210

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 12/7/2011

Title: Appeal of Paoze Her and Song Lor to a Fire Certificate of Occupancy Correction Notice at 1631 BIRMINGHAM STREET.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1631 Birmingham.appeal.11-14-11.pdf, 2. 1631 Birmingham St.Fire C of O Letter.11-3-11.pdf, 3. 1631 Birmingham St.Her Ltr 11-14-11.pdf

Date	Ver.	Action By	Action	Result
12/13/2011	2	Mayor's Office	Signed	
12/7/2011	2	City Council	Adopted	Pass
11/8/2011	1	Legislative Hearings	Referred	
11/1/2011	1	Legislative Hearings	Laid Over	

Appeal of Paoze Her and Song Lor to a Fire Certificate of Occupancy Correction Notice at 1631 BIRMINGHAM STREET.

#2, 3, 4, 5 - These windows are the original windows from when the house was built. We did not modify or replace any windows in this house or alter any window ?? in the home.

October 4, 2011

Yes, bedroom NW side - 8 inches minimum sill height, if 2 standard size steps installed for the length of the window. Hearing necessary on the balance of the appeal.

WHEREAS, in the matter of the Appeal of Paoze Her and Song Lor to a Fire Certificate of Occupancy Correction Notice at 1631 BIRMINGHAM STREET the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council Grant a variance on the minimum sill height of the egress window provided 2 standard size steps are installed; and Deny the appeal on the egress bedroom window egress dimensions and grant an extension for 90 days to bring the windows into compliance; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.