



Legislation Details (With Text)

File #: RLH FCO 13- 170 **Version:** 2
Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed
In control: City Council
Final action: 8/21/2013
Title: Appeal of Tammi Timm to a Correction Notice-Daycare Inspection at 1341 ROSS AVENUE.
Sponsors: Kathy Lantry
Indexes: Correction Order, Ward - 7, Windows
Code sections:
Attachments: 1. 1341 Ross Ave.appeal.7-17-13, 2. 1341 Ross Ave.Timm Ltr. 7-24-13

Date	Ver.	Action By	Action	Result
8/27/2013	2	Mayor's Office	Signed	
8/21/2013	2	City Council	Adopted	Pass
7/23/2013	1	Legislative Hearings	Referred	

Appeal of Tammi Timm to a Correction Notice-Daycare Inspection at 1341 ROSS AVENUE.

Windows in sleeping rooms are 33 inches wide and open 17 inches high (instead of the 20 side and 24 high). These windows are in the original window openings. I've lived here 19 years and replaced windows about 15 years ago so the windows are not original. These are main floor windows.

July 2, 2013

James Perucca

No hearing necessary.

Yes, a 7 inch variance for the egress opening height of the listed windows.

WHEREAS, in the matter of the Appeal of Tammi Timm to a Correction Notice-Daycare Inspection at 1341 ROSS AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of the egress windows in the northeast and southeast bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.