



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
60

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 6/15/2011

Title: Appeal of Tong Khang to a Correction Notice-Complaint Inspection at 192 WHEELLOCK PARKWAY WEST.

Sponsors: Lee Helgen

Indexes: Ward - 5, Windows

Code sections:

Attachments: 1. 192 Wheelock.appeal.5-24-11.pdf

Date	Ver.	Action By	Action	Result
6/20/2011	2	Mayor's Office	Signed	
6/15/2011	2	City Council	Adopted	Pass
5/24/2011	1	Legislative Hearings	Referred	

Appeal of Tong Khang to a Correction Notice-Complaint Inspection at 192 WHEELLOCK PARKWAY WEST.

3 windows together grouped up
17" by 48"

When we bought the house, the windows were like this already.

May 12, 2011

Yes. 3 inches in the openable width for egress windows in daycare.

WHEREAS, in the matter of the Appeal of Tong Khang to a Correction Notice-Complaint Inspection at 192 WHEELLOCK PARKWAY WEST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; And

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable width of the egress bedroom windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.