



Legislation Details (With Text)

File #: RLH FCO 13- 168 **Version:** 2
Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed
In control: City Council
Final action: 8/21/2013
Title: Appeal of Michael and Stephanie Huber to a Correction Notice-Fostercare Inspection at 1697 HUBBARD AVENUE.
Sponsors: Russ Stark
Indexes: Ward - 4
Code sections:
Attachments: 1. 1697 Hubbard Ave.appeal.7-17-13, 2. 1697 Hubbard Ave.Huber Ltr. 7-24-13

Date	Ver.	Action By	Action	Result
8/27/2013	2	Mayor's Office	Signed	
8/21/2013	2	City Council	Adopted	Pass
7/23/2013	1	Legislative Hearings	Referred	

Appeal of Michael and Stephanie Huber to a Correction Notice-Fostercare Inspection at 1697 HUBBARD AVENUE.

Bedroom egress windows

July 12, 2013

James Perucca

No hearing necessary.

Yes, 7 inches on egress opening height for listed windows.

WHEREAS, in the matter of the Appeal of Michael and Stephanie Huber to a Correction Notice-Fostercare Inspection at 1697 HUBBARD AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of the egress windows in the main floor northeast and northwest bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.